



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No F.6 DFS/MS/School/2022/SZ/ 1260

Dated: 24 / 11 / 2022

FIRE SAFETY CERTIFICATE

Certified that **Delhi Public School, (International) Primary & Nursery School** at Sector-10, R.K Puram, New Delhi-110022 comprised of Basement (Storage only), Ground plus two upper floors owned/occupied by Delhi Public School was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2019/SZ/2211 dated 25-11-2019. The said premise was re-inspected by officer concerned of this department on 13/11/2022 in presence of Mr. Sarvani Rao (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 24 / 11 / 2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 24 / 11 / 2022 at New Delhi by

**(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE**

Copy to: -

1. The Principal, Delhi Public School, (International) Primary & Nursery School) Sector- 10, R.K Puram, New Delhi-110022
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The basement shall be used as per the provisions of BBL /NBC Part- IV.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."


N/8



INSPECTION REPORT

1	Name & Address of the Building	Delhi Public School, (International) Primary & Nursery School) Sector- 10, R.K Puram, New Delhi-110022		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Basement, (Storage Only) Ground + 02 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2019/SZ/2211 dated 25-11-2019		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2003/2192 dated 19/09/2003		
7	Date of Inspection	13-11-2022		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Sarvani Rao (Principal)		
10	Year of construction	2003		
11	Applicant letter No.	DPSI/Estate / 1322 dated 01-11-2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mtr 05 mtr N/A	09 mtr Provided N/A	MR MR N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	03 Provided	MR
	➤ Basement floor.	02 Nos	03 Provided	MR
	b) Width of Staircase			
	➤ Upper floors	Required	1.37m, 1.30m & 1m	MR
	➤ Basement floor	Required	1.38m, 1.37m & 1m	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	1.5m	Provided	MR
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	Required N/A N/A N/A N/A	Provided N/A N/A N/A N/A	MR N/A N/A N/A N/A
4	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	30 ACPH 12 ACPH	Exhaust fan provided Natural ventilation	MR MR
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	ISI marked	52 Nos ABC & W.CO ₂ Provided	MR MR MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	Hose Reel	UF- 03 Nos Basement- 02 Nos 30m 5mm	MR MR MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's location 	Smoke Ground floor N/A N/A N/A	Provided Provided N/A N/A N/A	MR MR N/A N/A N/A

2/9



Delhi Fire
The fire protection
time of inspec
Keeping
meas

8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required N/A N/A	Provided N/A N/A	MR N/A N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box 	100mm UF- 03 Nos Basement- 02 Nos UF- 03 Nos Basement- 02 Nos	100mm UF- 03 Nos Basement- 02 Nos UF- 03 Nos Basement- 02 Nos	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose box 	N/A N/A	Provided Provided	N/A N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump Head of main pump Number of main pumps Jockey Pump output Jockey Pump head Standby Pump output Standby Pump head Auto Starting/Manual Stopping Pump house access Terrace Level <ul style="list-style-type: none"> Discharge of pump Head of pump Power supply Auto starting of pump 	1260 LPM 70 m 01 180 LPM 70 m 1620 LPM 70 m Required Required	2280 LPM 70 m 01 180 LPM 70 m 2280 LPM 70 m Provided Provided	MR MR MR MR MR MR MR MR MR MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	50,000 ltrs N/A N/A N/A 10,000 Ltr	Provided N/A N/A N/A 20,000 Ltr	MR N/A N/A N/A MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft Pressurization of lift lobby Communication in lift car Fireman's switch Lift signage 	N/A N/A N/A Required Required	N/A N/A N/A Provided Provided	N/A N/A N/A MR MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A N/A	N/A N/A	N/A N/A
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel Flow switch panel PA system panel Battery backup Building floor plan 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

N/110



Delhi Public School, (International) Primary & Nursery School, Sector- 10, R.K Puram, New Delhi - 110022

MR MF The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No F 6/DFS/MS/School/2019/SZ/2211 dated 25-11-2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

1/14
16/11/22

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

1/14
16/11

~~DO (SZ)~~

F.T.

~~ADO (BCP)~~

As approved, F.T. letter is put up for your signature pl

1/14
18/11/22

~~DO (SZ)~~

M.S.