

C-24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110 001.**


No.F.6/DFS/MS/School/2022/ SZ/ 1298

Dated: 7/12/22

**FIRE SAFETY CERTIFICATE**

Certified that the building of S.D.M.C. School, New Roshanpura-II, Najafgarh, New Delhi-110043, is comprised of Three blocks namely Block-A, Block-B & Block-C, Block-A is comprised of ground plus two upper floors, Block-B is comprised of ground plus one upper floor and Block-C is comprised of ground floor only was issued fire safety certificate vide letter No. F.6/DFS/MS/School/2019/SZ/1969 dated 15/10/2019. The school building was re-inspected by the officer concerned of this department on 15/11/2022 in the presence of Smt. Anita Rani (Principal) and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....7/12/22..... at New Delhi.

  
( Sunil Chawdhary )  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Principal,  
S.D.M.C. School, New Roshanpura-II,  
Najafgarh, New Delhi-110043.
2. Director of Education,  
S.D.M.C, Civic Centre,  
Minto Road, New Delhi-110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/18

N/A

### INSPECTION REPORT

1. Name & address of the building : S.D.M.C. Primary School, New Roshanpura-II, Najafgarh, New Delhi-110043
2. Building comprised of : 3 blocks (A block G+2, B block G+1 & C block gr. floor only)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2019/SZ/1969 dated 15/10/2019
6. Fire Safety directives letter No : N/A
7. Date of inspection : 15/11/2022
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers  
From the building side : Smt. Anita Rani (Principal)
10. Year of Construction : 2012-2013
11. Applicant's letter No. : Nil dated 15/10/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible 06 mtrs. 4.5 mtrs N/A	Provided 3.85mtrs. N/A	MR MR, being old case N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	01 No in Blk-A, 01 no. in Blk-b, N/A	02 No's in Blk-A, 01 no. in Blk-b N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.50 m N/A N/A N/A	1.50 & 1.45 in Blk-A & 1.72m in Blk-B N/A N/A N/A	MR N/A N/A N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Required 1.50 m	Provided 2.40 m in Blk-A & 2.13 m in Blk-B	MR M/R
	d. No. of continuous staircases to terrace	1.0 m	1.16 m (double door)	M/R
	e. Width of Corridor			
	f. Class room Door Size			
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	N/A Required	N/A Natural ventilation	N/A M/R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	10 no's ABC/CO <sub>2</sub> type ISI marked	Provided Provided Provided	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	One 30 mtrs 5 mm	Provided Provided Provided	MR MR MR

N/B

7.	<b>Automatic fire detection and alarming system</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pump House Access</li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		450 LPM	Provided	M/R
		30 mtrs	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	N/A	N/A
		10000 ltrs	Provided	M/R
		Required	Provided	M/R
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>			(No Lift)
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	<b>Standby power supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19.	<b>Fire Control Room</b>			

1-

Detector  
Flow  
P

N/20

N/A	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
N/A		N/A	N/A	N/A
N/A		N/A	N/A	N/A
N/A		N/A	N/A	N/A
N/A		N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2019/SZ/1969 dated 15/10/2019 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*R. K. Yadav*  
21/11/2022

Signature of Inspecting Officer  
Name:- R.K. Yadav  
Designation:- Asstt. Divisional Officer

D.O. (South West)

*ah*  
21/11/22  
*Dy CEO (SZ)*

*FT*  
*ah*

*A.P.O/S.K.P.*

*FT letter is put up for sign. please*

*DY CEO (SZ)*

*ah*

*on S. all*

*R. K. Yadav*  
23/11/2022