

c-33

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No. F6/DFS/MS/2022/School/NW2/1301

Dated: 07/12/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Silver Oak Public School, A-1, Swaroop Nagar, Delhi-110042** located in **basement, Ground and 02 upper floors of a premise** comprised of **basement, Ground & three upper floors (3<sup>rd</sup> floor used as residence by owner)** owned/ occupied by **Silver Oak Public School** was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/2018/WZ/2397 dated 25.10.2018**. The premise was re-inspected by the officer concerned of this department on **22.11.2022** in the presence of **Sh. Rakesh Saini (Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from **07/12/2022** for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **07/12/2022** at New Delhi by

  
(Dharmpal Bhardwaj)  
Dy. Chief Fire Officer  
Ph:-011-23414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Silver Oak Public School located at A-1, Swaroop Nagar, Delhi-110042.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

**INSPECTION REPORT**

- 1 Name & address of the building : Silver Oak Public School at A-1, Swaroop Nagar, Delhi-110042
- 2 Type of Occupancy : Educational
- 3 Composition of building : Basement, Ground & 03 upper floors **but school is running at basement, ground & second floor only** and 3<sup>rd</sup> floor used for owner residence purpose
- 4 Type of Case : Renewal
- 5 Details of previous NOC : F6/DFS/MS/2018/WZ/2397 dated 25 10 2018
- 6 Fire Safety directives letter No : Nil
- 7 Date of inspection : 22 11 2022
- 8 Name of the Inspecting Officers : ADO (RN)
- 9 Name and designation of officers from the building side : Sh Rakesh Saini (Manager)
- 10 Year of Construction : 2004/2013
- 11 Applicant's letter No : Letter No. Nil DFS Dairy No 8121 Dated: 17 11 2022

Plot Area- 1300 sq.y		Covered Area: 2000 sq.y		class rooms -12+02		Students---40 nos	
Minimum Standards on fire prevention and fire safety U/R 33		NBC Part -IV Requirement		Provided at site		Remarks MR/NMR	
1	<b>Access to building</b>		06m	09m			MR
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	4.50m	3.90m & 2.90m			MR(old case)	
		NA	6m			NA	
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>						
	a	Number of staircases	02	03			MR
		<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02	03			MR
	b	Width of staircases	1.50m	1.50m x 2 & 90 cm			MR
		<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	1.50m	1.50m x 2 & 90 cm			MR
	c	Protection of exits					
		<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA	NA			NA
			NA	NA			NA
	d	No. of continuous staircases to terrace	2	2			MR
	e	Width of Corridor	1.50m	2.10m			MR
	f	Door Size	1 m	1.11m			MR
	3	<b>Compartmentation.</b>					
<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>		NA	NA			NA	
		NA	NA			NA	
		NA	NA			NA	
		NA	NA			NA	
		NA	NA			NA	
	NA	NA			NA		
4	<b>Smoke Management System.</b>						
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	12 a/c per hour	Exhaust Fan			MR	
		12 a/c per hour	Natural Ventilated			MR	
5	<b>Fire Extinguishers</b>						
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI marking</li> </ul>	10nos	15nos			MR	
		ABC Co2	ABC ---15			MR	
		ISI Marked	Yes			MR	

*(Handwritten signature)*


6	<b>First-Aid Hose Reels.</b>			MR
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			NA
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			MR
	• Basement	Required	Provided	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			MR
	• Size of riser/down-comer	100mm	100mm	MR
	• Number of hydrants per floor	01	01nos	MR
	• Hose Box	01	01nos	MR
12	<b>Yard Hydrants.</b>			NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			NA
	➤ Discharge of main Pump	N/A	N/A	NA
	➤ Head of Main pump	N/A	N/A	NA
	➤ Number of main pumps	N/A	N/A	NA
	➤ Jockey Pump out put	N/A	N/A	NA
	➤ Jockey pump head	N/A	N/A	NA
	➤ Standby Pump out put	N/A	N/A	NA
	➤ Standby Pump Head	N/A	N/A	NA
	➤ Auto Starting/ Manual stopping	N/A	N/A	NA
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	900LPM	900 LPM	MR
	➤ Head of the pump	40m	40m	MR
➤ Power Supply	N/A	N/A	NA	
➤ Auto Starting of pump	N/A	N/A	NA	
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N/A	N/A	NA
	➤ Draw-off connection	N/A	N/A	NA
	➤ Fire service inlet	N/A	N/A	NA
	➤ Access to tank	N/A	N/A	NA
	• Overhead Tank capacity	15,000 LTR	15,000 LTR	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part 4, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 2397 dated 25.10.2018.


~~DO (WZ)~~

~~By  02/12/2022~~


~~ADO/R.N~~


~~By  (WZ)~~

not any



As approved, F.T. letter is put up for your signature pl.

 ADO (WZ)  
 Signature of the Inspecting Officer  
 Name - A.C.L. Meena  
 Designation - ADO/RN

 06/12/2022  
 ADO (WZ)