

C-30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2022/SZ/ 302

Dated: 08/12/22

FIRE SAFETY CERTIFICATE

Certified that the **Star Shine Public School**, F-66/1, Green Avenue, Shiv Vihar (Near Indcare), Vikas Nagar, New Delhi-110059, comprised of ground plus one upper floor, owned/occupied by Star Shine Public School was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2019/SZ/446 dated 28/02/2019. The school was re-inspected by the officer concerned of this department on 14/03/2022 in the presence of Sh. Mahender Rampal (Manager) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....08/12/22..... at New Delhi.


(SUNIL CHAUDHARY)
DY.CHIEF FIRE OFFICER

Copy to:-

1. The Manager,
Star Shine Public School, F-66/1,
Green Avenue, Shiv Vihar (Near Indcare),
Vikas Nagar, New Delhi-110059.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/20

INSPECTION REPORT

Name & address of the building : Star Shine Public School, Plot No. 84-85, Block K-5, Mohan Garden
 Building comprised of : Near Vikrant Chowk, Uttam Nagar, New Delhi-110059
 Type of Occupancy : ground plus two upper floors
 Type of Case : Educational
 Details of Previous NOC : Renewal
 Fire Safety directives letter No : F.6/DFS/MS/School/2020/SZ/62 dated 19/02/2020
 Date of inspection : N/A
 Name of Inspecting Officer : 28/11/2022
 Name and designation of officers : A.D.O. R.K.Yadav
 From the building side : Sh. Mangla Rampal (Manager)
 Year of Construction : 2004-2005 (GF, FF) & Before 2016 (SF)
 Applicant's letter No. : Nil dated 21/11/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Cir. Dt. 01.03.2011 & UBBL-16 requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	4.5 mtrs. Directly accessible from road N/A	M/R, being old case M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 No.'s N/A	02 No.'s N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 & 1.35 m N/A	1.50 m each N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required 1.50 m	Provided 1.80 m	MR MR
	e. Width of Corridor	1.0 m on GF & FF & 1.20 m on SF	.85 m on GF & FF & 1.20 m on SF	MR on GF & FF being old case MR on SF
	f. Class Room Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation provided	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	07 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	MR MR MR

9/

N/21

Provision of

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 mtrs 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A 450 LPM 30 mtrs Required Required	N/A Provided Provided Provided Provided	N/A MR MR MR MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A	N/A N/A N/A N/A	N/A N/A N/A N/A
15.	Exit Signage.	10000 ltrs Required	Provided Provided	MR MR

✓

N/22

Provision of Lifts.		No Lift		
17.	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/School/2020/SZ/62 dated 19/02/2020 renewal under the Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
27/11/2022

Signature of Inspecting Officer
Name:- R.K. Yadav
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

hvt
1/12/22

Dyeco (S2)

F-1.

[Signature]

ADR JKD
F-T helter to put up for sign
Dyeco (S2)

put up for sign
8/11/2022

M.L. [Signature]