

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2022/WZ/Cos/ 567

Dated: 13/12/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Arora Natural Cosmetic, located at H-199, Sec-5, DSIIDC, Bawana, Delhi-110039 comprised of Basement+Ground+First Floor owned/occupied by M/s Arora Natural Cosmetic have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 01/12/2022 in the presence of Sh. Suraj Chhabra and that the building premise is fit for occupancy under "Class Industrial Building G-2(ii)" with effect from 13/12/2022..... for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/12/2022..... at New Delhi

(Atul Garg)
Director
Ph. 011-23414000

olea

Conditions for the validity of Fire Safety Certificate:

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Copy to :-

1. M/s Arora Natural Cosmetic, H-199, Sector-5, Bawana Industrial Area, Delhi-39.
2. Dy. Drug controller /licensing authority Govt. of NCT. Of Delhi, Drug Controller Department, F-17, Karkardooma, Delhi-110032.

INSPECTION REPORT

1. Name & address of the building: M/s Arora Natural Cosmetic located at H-199, Sector-5
Bawana Industrial Area, Delhi-39
2. Type of Occupancy : Industrial G-2(ii)
3. Building Comprised : **Basement+Ground+ First Floor.**
4. Type of Case : New Case
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : F6/DFS/MS/BP/2022/1660 Dated- 07/07/2022
7. Date of inspection : 01.12.2022
8. Name of the Inspecting Officer : ADO, R.K.Sinha.
9. Name and designation of officers
from the building side : Sh. Suraj Chhabra
9. Year of Construction : ---
10. Applicant's letter No. : E mail id, Dated-16/11/2022

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m	06 m	MR
	• Gate width	4.5 m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	1.50 m & 1.25 m	Provided	MR
	• Basements	1.25 m each	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR

R

n-4

	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.25 m	Provided	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	12 a/c per hour	Exhaust Fan Provided	MR
	• Upper floors	12 a/c per hour	Exhaust Fan Provided	MR
5	Fire Extinguishers			
	• Total numbers	10 nos	17 nos	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	Required	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10.	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR

nr

N-5

JA

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Terrace level Discharge of pump Head of the pump Power Supply Auto Starting of pump 	900 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		20,000 ltrs	20,000ltrs	MR

M

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	HT & LT panels shall be separated by walls of 2 hours fire resistance rating. all fittings shall be ISI marked	Provided	MR

The fire protection systems provided in the building were tested/ checked randomly and found functional at the time of inspection.

In view the substantial compliance of the minimum standard on fire prevention and fire safety required under the rules, it is recommended to grant fire safety certificate under Delhi Fire Service Rules, 2010.

(Signature)
 ADO/BW
 05/12/22

Signature of the Inspecting Officer
 Name: - Rajeev Kumar Sinha
 Designation-ADO/BW

(Signature)
 ADO/BW

(Signature)
 06/12/2022

(Signature)
 ADO/BW

(Signature)
 9/12/22

(Signature)
 9/12/2022

(Signature)
 ADO/BW