



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2022/ 576

Dated: 16/12/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s **Arya Samaj Mandir** located at **Sector B-2, Arya Samaj Marg, Vasant Kunj, New Delhi - 110070** building comprised of **Ground plus one upper floor** owned/occupied by **Arya Samaj Mandir**, was granted FSC by this department vide letter No. **F6/DFS/MS/2019/SZ/1689** dated **28/08/2019**. The premises was inspected by the officer concerned of this department on **05/12/2022** in the presence of Mr. Ankit Arya and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy "**Assembly**", Group-D (Mandir) with effect from ~~16/12/2022~~ **16/12/2022** for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued ~~16/12/2022~~ at New Delhi by.


(SUNIL CHAUDHARY)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to:-

The Manager, Arya Samaj Mandir,
Sector B-2, Arya Samaj Marg, Vasant Kunj,
New Delhi-110070.

Condition for the validity of fire safety certificate

- 1 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 7 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".



- N/10 -



INSPECTION REPORT				
1	Name & address of the building	M/s Arya Samaj Mandir Sector B-2, Arya Samaj Marg, Vasant Kunj, New Delhi - 110070		
2	Type of Occupancy	Assembly Building (Mandir)		
3	Type of Case	Ground + 01 upper floor		
4	Details of previous FSC	Renewal		
5	Fire Safety directives Letter No.	F6/DFS/MS/2019/SZ/1689 dated 28/08/2019		
6	Date of inspection	F6/DFS/BP/2013/304 dated 03/10/2013		
7	Name of the Inspecting Officer	05/12/2022		
8	Name and Designation of Officer from the building side	M. K. Sharma DO/SD		
9	Year of Construction	Mr. Ankit Arya		
10	Applicant's letter No./ Online Id No.	2016		
		Outdoor diary no. 5865 dated 20/09/2022		
Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	Requirements	Provided at Site	Remarks
1	Access to Building			MR/NMR
	1 Road Width	09 mtr.	09 mtr.	MR
	2 Gate Width	4 mtr.	4 mtr.	MR
	3 Width of Internal Road	N/A	N/A	MR
2	Number, Width, Type & Arrangements of exits			N/A
	A Number of Staircase			
	1 Upper Floors	02 nos.	02 nos.	MR
	2 Basement	N/A	N/A	N/A
	B Width of Staircase			
	1 Upper Floors	02 mtr.	2 mtr. (each)	MR
	2 Basement	N/A	N/A	N/A
	C Protection of Exits			
	1 Fire Check door	N/A	N/A	N/A
	2 Pressurization	N/A	N/A	N/A
	D No. of Continuous S/C to terrace	01 no.	02 nos.	MR
	E Width of Corridor	N/A	N/A	N/A
	F Door Size	2 mtr.	4 mtr. 04 nos.	MR
3	Compartmentation			
	1 Fire check door	N/A	N/A	N/A
	2 Sealing of electrical shafts	Required	Provided	MR
	3 Fire rating of shaft door	N/A	N/A	N/A
	4 Water curtain	N/A	N/A	N/A
	5 Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	1 Basements	N/A	N/A	N/A
	2 Upper floors	N/A	N/A	N/A
5	Fire Extinguishers			



	1 Total Numbers	06 Nos.	06 Nos.	MR
	2 Types	ABC & CO2	ABC & CO2	MR
	3 ISI Marking	Required	Provided	MR
6	First-Aid Hose Reel			
	1 Total number on each floor	01 No.	Provided	MR
	2 Length of hose reel hose	30 mtr.	Provided	MR
	3 Nozzle diameter	05 mm	Provided	MR
7	Automatic Fire Detection & Alarming System			
	1 Type of detectors	N/A	N/A	N/A
	2 Location of main panel	N/A	N/A	N/A
	3 Location of repeater panel	N/A	N/A	N/A
	4 Alternate source of power	N/A	N/A	N/A
	5 Hooter's Location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	1 Basement	N/A	N/A	N/A
	2 Upper floors	N/A	N/A	N/A
	3 Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	1 Size of riser/down-comer	100 mm	Provided	MR
	2 Number of hydrants per floor	01 No.	Provided	MR
	3 Hose box	01 No.	Provided	MR
12	Yard Hydrants			
	1 Total number of hydrants	N/A	N/A	N/A
	2 Hose box	N/A	N/A	N/A
13	Pumping Arrangement			
	A Ground level			
	1 Discharge of main pump	N/A	N/A	N/A
	2 Head of main pump	N/A	N/A	N/A
	3 Number of main pump	N/A	N/A	N/A
	4 Jockey pump out put	N/A	N/A	N/A
	5 Jockey pump head	N/A	N/A	N/A
	6 Stand by pump output	N/A	N/A	N/A
	7 Stand by pump head	N/A	N/A	N/A
	8 Auto starting/Manual stopping	N/A	N/A	N/A
	B Terrace level			
	1 Discharge of pump	900 LPM	900 LPM	MR
	2 Head of pump	40 m	40 m	MR
	3 Power supply	Required	Provided	MR
	4 Auto starting of pump	Required	Provided	MR
14	Capacity of Water Storage for Fire Fighting			
	1 Underground tank capacity	N/A	N/A	N/A
	2 Draw-off connection	N/A	N/A	N/A
	3 Fire service inlet	N/A	N/A	N/A
	4 Access to tank	N/A	N/A	N/A
	5 Over head tank capacity	15,000 ltr.	15,000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	1 Pressurization of lift shaft	N/A	N/A	N/A

MA

	2 Pressurization of lift lobby	N/A	N/A	N/A
	3 Communication in lift car	N/A	N/A	N/A
	4 Fireman's switch	N/A	N/A	N/A
	5 Lift signage	N/A	N/A	N/A
17	Stand by Power Supply	N/A	N/A	N/A
18	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19	Fire Control Room			
	1 Detector system panel	N/A	N/A	N/A
	2 Flow switch panel	N/A	N/A	N/A
	3 PA system panel	N/A	N/A	N/A
	4 Battery backup	N/A	N/A	N/A
	5 Building floor plan	N/A	N/A	N/A
20	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection and the system is common with whole building.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/2019/SZ/1689 dated 28/08/2019, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended.

musk
13/12

Signature of the Inspection Officer
Name :- M.K. Sharma
Designation:- DO/SD

Dy.CFO/SZ

[Handwritten signature]
[Handwritten signature]
M.K. Sharma

F.T. letter is put up for sig. pl

DEPS(SZ)
[Handwritten signature]

musk
13/12
M.S. Gill