

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/CNG/2022/SZ/ 569

Dated: 14/12/2022

FIRE SAFETY CERTIFICATE

Certified that the CNG Station at Khasra No. 105/21/2 Village- Jharoda Kalan, Delhi, comprised of ground floor only, (03 Dispenser with 06 points) owned/occupied by **M/s Indraprastha Gas Limited**. The premises was inspected by the officer concerned of this department on 05/12/2022 in the presence of Sh. Kuldeep Dahiya (Manager) and found that CNG Dispensing Station have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises (**CNG Dispensing Station**) is fit for occupancy Class "J" Hazardous Building w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on... 14/12/2022at New Delhi.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

9/cq <

Copy to:-

1. The Manager,
CNG Station at Khasra No. 105/21/2 Village- Jharoda Kalan, Delhi.
2. The Joint C.P. (Lic.),
Police Station, Defence Colony, New Delhi

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

KJS

INSPECTION REPORT

- Name & address of the building : CNG Station at Khasra No. 105/21/2 Village- Jharoda Kalan, Delhi.
2. Type of Occupancy : Group "J" Hazardous (CNG Facility)
3. Building comprised of : Ground floor only.
4. Type of Case : New
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : F6/DFS/MS/BP/2019/CNG/900 dated 15/02/2019
7. Date of inspection : 05/12/2022
8. Name of Inspecting Officer : ADO R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Kuldeep Dahiya (Manager)
10. Year of Construction : 2020-21
11. Applicant's letter No. : Nil dated 31/10/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NFPA/CCOE/OISD etc. requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<p>12 m</p> <p>NA</p> <p>NA</p>	<p>54 m Provided</p> <p>Directly accessible from road</p> <p>NA</p>	<p>MR</p> <p>NA</p> <p>NA</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
	d. No. of continuous staircases to terrace			
		NA	NA	NA
	e. Width of Corridor			
		NA	NA	NA
	f. Door Size			
		NA	NA	NA
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08 Nos.	Provided	MR
		Required	4 Nos. DCP Type (9 kg), 4 Nos. CO2 Type 4.5 kg, 2 Nos. DCP Type (75 kg) trolley mounted	MR
		ISI	Provided	MR

RS

5.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Gas and flame detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Required	Provided	MR
		Required	Office at GF	NA
		NA	NA	NA
		Required	Provided	MR
		Required	At station	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Ground Floor • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	No Smoking Signage.	Required	Provided in Hindi & English	MR

11/12

NA
NA
NA

Provision of Lifts.

	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	Provided (DG Set)	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	CO ₂ flooding system in compressor	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 (3) of the Delhi Fire Service Rules 2010.

Note: Sand buckets are provided in the premises & No smoking boards adequately displayed in English and Hindi.

Advance fire water mist cum foam trolley is provided.
Two hand held explosive meters are also provided.

R.K. Yadav
01/12/2022

Signature of Inspecting Officer
Name:- R.K.Yadav
Designation:- Asstt. Divisional Officer

D.O (South West)

12/12/22
Dy. Chd (S/W)

13/12

H.O. 13/12/2022
Director
AD/JP