

306/HDO/DWK
FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS /SZ/2022/ 572

Dated: 16/12/2022

FIRE SAFETY CERTIFICATE

Certified that the building GGSIP University Located at Sector 16 C, Dwarka, New Delhi (Boys hostel 1 & II, Girls Hostel I & II) comprised of G+ 09 UFs was issued Fire Safety Certificate vide letter No: F6/DFS/MS/2012/120, dated 13/01/2012 & F6/DFS/MS/2012/1470, dated 24/04/2012. The premises was re - inspected by the team of officers concerned of this department on 07/12/2022 in the presence of Sh. Deepesh Singh Bhati A.E(E) & his team and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Residential" **Group A-1 (Hostel Block)** with effect from 16/12/2022 for a period of five years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on16/12/2022... at New Delhi by.


(Ajul Garg)
Director
Delhi Fire Service

Copy to:

1. The Registrar (E&S), GGSIPU, Sector-16-C, Dwarka, New Delhi-110078.
2. The Astt. Registrar to the Hon'ble Vice Chancellor, GGSIPU, Sector-16-C, Dwarka, New Delhi-110078.
3. The Executive Engineer (UWD, GGSIPU) University Works Division, Ground Floor, Library Block, Guru Gobind Singh Indraprastha University, Sector 16-C, Dwarka New Delhi-110078.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

n/73
INSPECTION REPORT

- for sign
1. Name & address of the building: GGSIP University Located at Sector 16C, Dwarka, New Delhi.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Boys hostel 1& II, Girls Hostel I & II, Residential type IV & V G+9 UFs)
4. Details of previous NOC : F6/DFS/MS/2012/120, dated 13/01/2012 & F6/DFS/MS/2012/1470, dated 24/04/2012
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2006/1208, dated 25/05/2006
6. Date of inspection : 07/12/2022
7. Name of the Inspecting Officer : DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Deepesh Singh Bhati A.E(E) & his team
9. Year of Construction : 2006
10. Applicant's letter No. : Email dated-25/12/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement As per N/46, N/47 & N/48	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtrs	Provided	MR
	• Gate width	05 mtrs	Provided	MR
	• Width of internal road	06 mtr	Old case	MR being old case
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 No's each block	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5mtr & 1.25 m each	Provided old case	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	1.5m	Provided (Old case)	MR
	f. Door Size	1.5 mtr	Provided (Old case)	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	Natural Ventilation	NA

DS

n/72

n/74

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 nos each floor WCO2 & CO2 ISI marked	45 Nos. Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 no 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA GF NA Required Near Staircase	NA Near main gate NA DG Set Provided	NA MR NA MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm 02 Nos. Required	150 mm Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required Required	Provided Provided	MR MR
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	2280 Lpm 70 mtr one 180 LPM 70 mtr 2850 LPM 70 mtr Required Required NA NA NA NA	Provided Provided Provided Provided Provided Provided Provided Provided Provided NA NA NA NA	MR MR MR MR MR MR MR MR MR NA NA NA NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	2,00,000 ltr Required Required Required 20,000 Ltr	Provided Provided Provided Provided Provided	MR MR MR MR MR
15	Exit Signage	Required	Provided	MR

n/75

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panels	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No F6/DFS/MS/2012/120, dated 13/01/2012 & F6/DFS/MS/2012/1470, dated 24/04/2012 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name: *Uday Vir Singh*
 Designation: *ADDP/DWR*

D/S/O *hsh* 9/12/22
Dy CFO (2) *hs* 12/12
CFO *Khushi* 12/12/2022
Director *hsh* 12/12/22
ADDP/DWR