

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/School/SZ/2022/ 1325

Dated: 14/12/22

FIRE SAFETY CERTIFICATE

Certified that **Nigam Adarsh Bal/Balika Vidyalaya located at 22-Block, West Patel Nagar, New Delhi- 110008**, was granted Fire Safety Certificate vide letter No. F6/DFS/MS/School/2019/SZ/1599 dated 09.08.2019 for the building comprised of ground floor only. The school building was re-inspected by the officer concerned of this department on 30.11.2022 in the presence of Mrs. Anju Gurdatta (Incharge of the school) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular No. F.16/Estate/CC/FireSafety/2011/3298 to 3398 dated 01.03.2011 and that the building/premises is fit for occupancy class "Educational" **(for ground floor only)** with effect from the date of issue of this certificate for a period of three years, subject to compliance of the under mentioned conditions.

Issued on 14/12/22 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Principal, Nigam Adarsh Bal/Balika Vidyalaya located at 22-Block, West Patel Nagar, New Delhi- 110008.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : Nigam Adarsh Bal/Balika Vidyalaya, 22-Block, West Patel Nagar, New Delhi- 110008..
2. Type of Occupancy : Educational
3. Building Composition : Said School Building comprised of ground floor only.
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2019/SZ/1599 dated 09.08.2019
6. Fire Safety directives letter No : Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011.
7. Date of inspection : 30.11.2022
8. Name of the Inspecting Officers : P.V. Rathee, Asstt. Div. Officer (SRD)
9. Name and designation of officers from the building side : Mrs. Anju Gurdatta (Incharge of the school)
9. Year of Construction : 1963
10. Applicant's letter No. : nil dated 02.11.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	05 mts	3.17 mts	MR, being old case
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	N/A	N/A	Ground floor only
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	N/A	N/A	Ground floor only
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	Ground floor only
	g. Width of Corridor	1.0 mts.	1.10 mts.	MR
	h. Door Size			
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	Ground floor only
5	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers Types IS marking 	03 nos. ABC/CO ₂ type ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
7	Automatic fire detection and alarming system	Not required		
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	--- N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	----- N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	----- N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.	Not Applicable		

	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any	N/A	N/A	N/A

The fire protection systems provided in the building were test checked at random and found satisfactory at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/School/2019/SZ/1599 dated 09.08.2019, renewal under the Directorate of Education circular No. F.16/Estate/CC/Fire Safety/201 /3298 to 3398 dated 01-03-2011 is recommended.

Accordingly, DFA is put up for approval & signature please.

[Handwritten Signature] 11/12/22

Signature of the Inspecting Officer
(P.V. Rathee)
Asstt. Div. Officer, (SRD)

[Handwritten Signature] D.O. (SW)

11/12/22 F.T.

[Handwritten Signature] Dy. CF O (SZ)

[Handwritten Signature] h

[Handwritten Signature] A.P.O.S.R.N

F.T. Letter is put up for sign. please

[Handwritten Signature] Dy. CF O (SZ)

[Handwritten Signature] h

[Handwritten Signature] 5/12/22

M.S. call