

C-18

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001


No.F6/DFS/MS/School/2022/SZ/312

Dated: 14/12/22

FIRE SAFETY CERTIFICATE

Certified that the R.P. Memorial Public School, K-3, Mohan Garden, Uttam Nagar, New Delhi-110059, comprised of ground plus three upper floors & four rooms at terrace floor which is use for residence purpose, owned/occupied by R.P. Memorial Public School was issued FSC vide letter No. F.6/DFS/MS/09/1617 dated 03.06.09 (For GF & FF only). The school building was inspected by the officer concerned of this department on 21/11/2022 in the presence of Sh. Ravinder Yadav (Manager) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....14/12/22.....at New Delhi by


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Principal, R.P. Memorial Public School, K-3, Mohan Garden, Uttam Nagar, New Delhi-110059.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

11/9

INSPECTION REPORT

1. Name & address of the building : R.P. Memorial Public School, K-3, Mohan Garden, Uttam Nagar, New Delhi-110059.
2. Building comprised of : School running at ground plus three upper floors & 4 Rooms at terrace floor which is use for residence purpose.
3. Type of Occupancy : Educational
4. Type of Case : Addition/alteration
5. Details of Previous NOC : F.6/DFS/MS/09/1617 dated 03.06.09 (For GF & FF Only)
6. Fire Safety directives letter No : N/A
7. Date of inspection : 21/11/2022
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Ravinder Yadav (Manager)
10. Year of Construction : Before 2009 (GF & FF) & 2017 (SF & TF)
11. Applicant's letter No. : Nil dated 18/11/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	10 mtrs 4.5 mtrs N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 No.'s	04 No.'s	M/R
	b. Width of staircases	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 m	1.80 m, 1.65 m, 1.35m & 1.40 m	M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	2 No.	Provided	M/R
	e. Width of Corridor	1.50 m	2.40 m	M/R
	f. Door Size	1.0 m	1.0 m	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	11 no's ABC/CO ₂ type ISI marked	Provided	M/R
			Provided	M/R
			Provided	M/R

9-

N/10

Division of Li
 Pressur
 Co
 F
 17.
 18.

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	02 no.	Provided	M/R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 mtrs	Provided	M/R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 			
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450 LPM	600 LPM & 270 LPM provided	M/R
	<ul style="list-style-type: none"> ➤ Head of the pump 	30 m	Provided	M/R
	<ul style="list-style-type: none"> ➤ Power Supply 	Required	Provided	M/R
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead Tank capacity 	10000 ltrs	Provided	M/R
15.	Exit Signage.	Required	Provided	M/R


N/11

Provision of Lifts.		No Lift		
M/R M'	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued vide letter No. F6/DFS/MS/School/SZ/3358 dated 08/12/2017 has been complied.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures under rule 35 of the Delhi Fire Service Rules 2010 it is recommended to grant Fire Safety Certificate.

Note:- Earlier NOC was issued vide letter no. F.6/DFS/MS/09/1617 dated 03.06.09 for Ground plus one upper floor.


 Signature of Inspecting Officer
 Name:-R.K. Yadav
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

