



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001




No. F.6/DFS/MS/Cinema/WZ/2022/ 580

Dated: 20/12/2022

FIRE SAFETY CERTIFICATE

Certified that the Cinapolis located at TDI Mall, Moti Nagar, New Delhi-110015 in a mall comprised of 02 Basement + Ground + 03 upper floors was issued FSC vide letter no. F6/DFS/MS/Cinema/WZ/2019/2276 dated 09/12/2019. The premises was re-inspected by the officer concerned of this department on 14/12/2022 in the presence of Sh. Ajay kumar (Unit Head Cinema Operation) found that the said building have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire service Rules, 2010 and that the said building/premise is fit for occupancy class "Assembly Building" Group D with effect from 20/12/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 conditions mentioned below.

Issued on20/12/2022 at New Delhi by.


(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi- 110049.
2. The SDM/HQ/DDMA, District West, 3, Shivaji palace, Raja Garden, New Delhi-110027.
3. The Authorized Signatory, Cinapolis located at TDI Mall, Moti Nagar, New Delhi-110015.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Cinepolis (Formally Known as Fun Cinemas) Located at TDI Mall, Moti Nagar, New Delhi-110015.
2. Type of Occupancy : Assembly (02 BASEMENT +Ground + 03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2019/2276 dated 09/12/2019
5. Fire Safety directives letter No. : F6/DFS/MS/BP/2002/1040 dated 02/07/2002 & F.6/DFS/Cinema/2004/BP/370 dated 16/02/2004
6. Date of inspection : 14/12/2022
7. Name of the Inspecting Officers : Sarabjeet Singh ADO(MN)
8. Name and designation of officers from the building side : Sh. Ajay kumar (Unit Head Cinema Operation)
9. Year of Construction : 2005 (As per insp. Report dtd- 13/11/2019)
10. Applicant's letter No. : Email dated 24/11/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement / As per prev. indp. Report dtd.-13/11/2019	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	20 mts	Provided	MR
	• Gate width	06 mts	Provided	MR
	• Width of internal road	06 mts	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	05 nos	005 nos Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	2 X2 mtr 3X 1.5 mtr	1x1.36m, 1x1.86m, 1x1.86m, 1X1.92m 1x1.41 m Provided	MR (old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	Old case	Old case	MR
	g. Door Size	Old case	Old case	MR
3	Compartmentation.			
	Common With Mall			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Found sealed	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR
4	Smoke Management System.			
	Common With Mall			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors (Audi 1 to 6)	12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	• Total numbers	03 nos. per Audi	Provided	MR
	• Types	CO ₂ , Wco ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 in each Audi	Provided	MR
		30 mm	Provided	MR
		05 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Beam	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required at Mall	Provided	MR
		Required at cinema	Provided	MR
		Required	Provided	MR
11	Internal Hydrants	Common with MALL		
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
12	Yard Hydrants.	Common With Mall		
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required	Provided	MR
		Required	Provided	MR
13	Pumping Arrangements.	Common With Mall		
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	2850 LPM	Provided	MR
		60 MH	Provided	MR
		02	Provided	MR
		180 LPM	Provided	MR
		60 MH	Provided	MR
		2850 LPM	Provided	MR
		60 MH	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
14	Captive Water Storage for fire fighting. Common With Mall			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	1,50,000 ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 ltrs	Provided	MR

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	Provided	NA
	• Pressurization of Lift lobby	NA	Provided	NA
	• Communication In lift Car	NA	Provided	NA
	• Fireman's Grounding Switch	NA	Provided	NA
	• Lift Signage	NA	Provided	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	Provided at terrace	NA
	➤ Location	NA	Provided	NA
19	Fire Control Room			
	• Detector System Panel	NA	Provided	NA
	• Flow Switch Panel	NA	Provided	NA
	• PA System Panel	NA	Provided	NA
	• Batter backup	NA	Provided	NA
	• Building Floor Plans	NA	Provided	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	Provided	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/Cinema/WZ/2019/2276 dated 09/12/2019, renewal under rule 35 of the Delhi Fire Service Rules 2010, is recommended.

~~DO/wsl~~

~~16/12/2022~~

~~DCS(MN)~~

~~16/12/22~~

~~CFO~~
~~16/12/2022~~

~~Director~~
~~19/12/22~~

~~15/12/22~~

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

~~DO/wsl~~