## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2022 /School/WZ/ 1339

Dated: 20/12/22

## FIRE SAFETY CERTIFICATE

Certified that Rama Devi Public School located at Dariyapur Road, Ghoga, Delhi110039 comprised of Ground Floor only owned/occupied by Rama Devi Public School was
issued FSC by this department vide letter No F6/DFS/MS/2019/WZ/465 dated 06.03.2019. The
premises was inspected by the officer concerned of this department on 14.12.2022 in the
presence of Sh. Balwant Goswami (Principal), and observed that all the fire prevention and fire
safety arrangements as provided in the premises found in good working condition. The premises
have deemed complied with requirements of circular issued by Director of Education letter no
3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B
Educational with effect from 200/11.2012................... for a period of three years, subject to
compliance of the conditions mentioned below:

Issued on . 20 [. 1.2 ] at New Delhi

Yours faithfully www

Dharampal Bhardwaj Dy. CHIEF FIRE OFFICER WEST ZONE

Copy to: -

1. The Director, Education, Old Secretariat, Delhi.

2. The Principal, Rama Devi Public School, Dariyapur Road, Ghoga, Delhi-39.

## Conditions for the validity of Fire Safety Certificate:

- 1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3. The trained fire fighting staff should be available round the clock.
- 4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

**INSPECTION REPORT** 

1. Name & address of the building: Rama Devi Public School, Dariyapur Road, Ghoga, Delhi-110039.

. Type of Occupancy : Educational

3. Building Comprised : Ground Floor Only.

4. Type of Case : Renewal

5. Details of Previous NOC : Letter No. F.6/DFS/MS/2019/WZ/465 Dated-06/03/2019

6. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011

7. Date of inspection : 14/12/2022 8. Name of Inspecting Officer : ADO, R.K.Sinha

9. Name and designation of officers

From the building side : Sh. Balwant Goswami (Principal)

10. Year of Construction : 2007

**11.** Applicant's letter No. : RDPS/12/2022, Dated-05/12/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR		
1.	Access to building					
	<ul> <li>Road width</li> </ul>	Accessible	Accessible	MR		
	<ul> <li>Gate width</li> </ul>	4.5 m	2.46 m	MR(old case)		
	<ul> <li>Width of internal road</li> </ul>	NA	NA	NA		
2.	Number, Width, Type & Arrangement of Exits					
	a. Number of staircases	NA	NA	NA		
	<ul> <li>Upper Floors</li> </ul>	NA	NA	NA		
	Basements	NA	NA	NA		
	<ul><li>b. Width of staircases</li><li>Upper Floor</li></ul>	NA	NA	NA		
		NA	NA	NA		
	Basements     C. Protection of exits	NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
	<ul><li>Fire check door</li><li>Pressurization</li></ul>	NA	NA	NA		
		NA	NA	NA		
	d. No. of continuous staircases to	NA	NA	NA		
	terrace	NA	NA	NA		
	e. Width of Corridor	147	1171	1177		
	f. Door Size	1.00 m	1 m with door fitting	MR(old case)		
3.	Compartmentation					
	<ul> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
		NΛ	NA	NA		
4.	Smoke Management System					
T a	Dimone Management System					

N-21

	N-4			(D		
	• Upper floors	NΛ	NA	MR		
•	Fire Extinguishers			MR		
	<ul> <li>Total numbers</li> </ul>	03	03	MR		
	• Types	ABC	ABC	MR		
	<ul> <li>1S marking</li> </ul>	Yes	Yes	MIK		
	First-Aid Hose Reels					
	Total numbers on each floor	NA	NA	NA NA		
	<ul> <li>Length of hose reel hose</li> </ul>	NA	NA	NA		
	Nozzle diameter	NA	NA			
7.	Automatic fire detection and alarming system		NA	NA		
•	Type of detectors	NA	NA	NA		
	Location of Main Panel	NA	NA	NA		
	Location of Repeater Panel	NA	NA			
	Alternate source of power	NA	NA	NA		
		NA	NA	NA		
	<ul> <li>Hooters' Location</li> </ul>	NA	NA	NA		
8.	MOEFA	NA NA	NA	NA		
9.	Public Address System					
10.	Automatic Sprinkler System					
	Basement	NA	NA	NA NA		
	Cound Floor	NA	NA			
	<ul><li>Ground Floor</li><li>Sprinkler above false ceiling</li></ul>	NA	NA	NA		
11.	Internal Hydrants					
	at a tilliam comer	NA	NA	NA		
	Size of riser/down-comer  Size of riser/down-comer  Size of riser/down-comer  Size of riser/down-comer	NA	NA	NA		
	Number of hydrants per floor     Hass Box	NA	NA	NA		
12.	Hose Box  Yard Hydrants					
		NA	NA	NA		
	<ul> <li>Total number of hydrants</li> </ul>	NA	NA	NA		
	Hose Box					
13.	Pumping Arrangements					
	<ul> <li>Ground Level</li> <li>Discharge of main Pump</li> </ul>	NA	NA	NA		
	Head of Main pump	NΛ	NA	NA		
	Number of main pumps	NA	NA	NA		
	Jockey Pump out put		NA	NA		
	Jockey pump head	NA				
	Standby Pump out put	NΛ	NA	NA		
	Standby Pump Head	NΛ	NA	NA		
	➤ Auto Starting/Manual Stopping	NΛ	NA	NA		

N-22

		N-LL		
	> Pump House Access	NA	NA	NA
	Terrace level			
	<ul> <li>Terrace level</li> <li>Discharge of pump</li> </ul>	NA	NA	NA
	> Head of the pump	NΛ	NA	NA
	> Power Supply	NΛ	NA	NA
		~	-	-
	> Auto Starting of pump	NΛ	NA	NA
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	> Access to tank	NA	NA	NA
	Overhead Tank capacity			
		NA NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.  • Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift Shart     Pressurization of Lift lobby			
	Communication In lift Car	NA NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	- I remail 5 Grounding 5 witch	NA	NA	NA
	Lift Signage	NA	NA	NA
		NA	NA	NA
17.	Standby power supply	7		
18.	Refuge Area.  Total Area	NA	NA	NA
	> Location	NA	NA	NA
19.	Fire Control Room	NIA	NIA	NA
	Detector System Panel	NA	NΛ	
	Flow Switch Panel	NΛ	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NΛ	NA	NA
	Building Floor Plans	NΛ	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NΛ	NA	NA

le