



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव


No. F6/DFS/MS/EH/WZ/2022/ 355

Dated: 20/12/22

FIRE SAFETY CERTIFICATE

Certified that M/s. Four on Forty Four (A unit of Shiva Enterprises) running at shop No. 112, First Floor, Aggarwal City Mall, Road No. 44, Pitampura, New Delhi, building comprised of basement, ground plus three upper floors, owned/occupied by M/s. Shiva Enterprises, was granted fire safety certificate by this department vide letter No. F6/DFS/MS/WZ/2019/2329 dated 17.12.2019. The premise was re-inspected by the officer concerned of this department on 13.12.2022 in the presence of Sh. Ajit (Manager) and observed that the management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class- "Assembly" Group-D (**Restaurant at first floor only**) with effect from 20/12/22 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 20/12/22 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to:-

1. The Owner / Occupier, M/s. Four on Forty Four (A unit of Shiv Enterprises), Shop No. 112, First Floor, Aggarwal City Mall, Road No. 44, Pitampura, New Delhi.
2. The Dy. Health Officer, MCD, Keshav Puram Zone, New Delhi.
3. The Joint Commissioner of Police (Lic.), Police Station Defence Colony, First floor, New Delhi.



Following Fire Safety Directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MHA portal (<https://www.delhlic.gov.in>) along with a copy of this certificate, six months prior to its expiry.
8. This FSC is valid for the Restaurant at First Floor only.

+1-19

INSPECTION REPORT

1. Name & address of the building: M/s. Four on Forty Four (A unit of Shiva Enterprises), Shop No. 112, FF, Agarwal City Mall, Road No. 44, Pitampura, New Delhi.
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2019/2329 dated 17.12.2022
5. Fire Safety directives letter No : N/A
6. Date of inspection : 13.12.2022
7. Name of the Inspecting Officers : M.K. Chattopadhyay, D.O (West)
8. Name and designation of officers from the building side : Sh. Ajit, Manager
9. Year of Construction : 2005
10. Applicant's letter No. : Online ID- 2022120321027

The said restaurant is running at first floor in a building comprised of basement, ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 36 (7)	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	Required	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	02	03	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	Old case	01x1.25, 02x1.18 mts	MR being old case
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	N/A	Provided	----
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	Provided	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	Required	1.10, 0.90 mts	MR being old case
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural ventilation	MR



11-20

14

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08 nos. CO ₂ , ABC type ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided	MR
			Provided	MR
			Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat	Provided	MR
		Ground Floor	Provided	MR
		On each floor	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA			
		Required	Provided	MR
9	Public Address System.			
		N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Entire Restaurant Sprinkler above false ceiling 	N/A	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	Provided	N/A
		N/A	Provided	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	---	---	---
		N/A	2280 lpm of the mall	N/A
		N/A	60 mtr	N/A
		N/A	02	N/A
		N/A	180 lpm	N/A
		N/A	40 m	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		-----	-----	-----
		900 LPM	Not Provided	MR as pumps at GF are at higher side
		40 mts	Not Provided	MR
		Required	Not Provided	MR
		Required	Not Provided	MR

M-21

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50,000 lts	50,000 lts	MR
		N/A	Provided	---
		N/A	Provided	---
		N/A	Provided	---
15	Exit Signage.	10,000 lts	Provided	MR
16	Provision of Lifts.	Required	Provided	MR
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked & found functional at the time of inspection.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, the NOC issued vide letter No. F6/DFS/MS/WZ/2019/2329 dated 17.12.2022 renewal under Rule 35 of Delhi Fire Service Rules 2010, is recommended.

Accordingly, DFA is put up please.

[Signature]
15/12/2022

M.K. Chattopadhyay
Divisional Officer (West)

~~Dy. CFO (WZ)~~
[Signature]
15/12/2022

~~MS/ West~~
~~DFO (WZ)~~
MS/ cell

Letter is put up for Sign please
[Signature]
18/12/22
uploaded
behals
20/12/22