

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2022/

587

Dated 23/12/2022

FIRE SAFETY CERTIFICATE

Certified that the **Shaheed Bhagat Singh Place** located at **Gole Market, New Delhi** comprised of **Basement + Ground + 03 Upper floors** owned/occupied by NDMC was earlier granted FSC by this department vide letter No.F6/DFS/MS/NDZ/2019/22 dated 03/01/19. Now, the premises was re-inspected by the officer concerned of this department on 14/12/22 in the presence of **Sh. Shokeen, fire officer, (NDMC)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Mercantile/Business Building**, with effect from ~~23/12/2022~~ for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ~~23/12/22~~ at New Delhi by.


(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Chief Architect,
NDMC, Palika Kendra, New Delhi.
2. N.K Gaur,
Fire Officer, NDMC, Palika Kendra, New Delhi.

Condition for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building **Shaheed Bhagat Singh Place at Gole Market, New Delhi**
2. Type of occupancy:- **Business Building
B + Gr. + 03 Upper floors**
3. Type of case:- **Renewal**
4. Details of previous FSC:- **No. F6/DFS/MS/NDZ/2019/22 dated 03/01/19.**
5. Fire safety directives No.- **N/A**
6. Date of inspection:- **14/12/22**
7. Name of the inspecting officer:- **Sh. Rajinder Atwal (DO/CD)
Sh. Ravinder Singh (ADO/CC)**
8. Name & designation of officer
From the building side:- **Sh. Shokeen (NDMC)**
9. Year of construction:- **1990-91**
10. Applicant's letter No:- **email <fo@ndmc.gov.in> dated 15.11.22.**

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	12 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	03 Nos.	MR
	2. Basements	02 Nos.	03 Nos.	MR
	B. Width of staircase			
	1. Upper floors	1.25 mtr.	1.19, 1.44 & 1.50 mtr.	MR
	2. Basements	1.25 mtr.	1.19, 1.44 & 1.50 mtr. & 2 ramps	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	01 nos	N/A
	E. Width of corridor	1.25 mtr.	Provided	MR
	F. Door size	01 mtr.	1.20 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 a/c per hour	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	60 Nos.	60 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR

	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	03	03	MR
	2) Length of hose reel hose	35 mtr.	35 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors, Heat/Smoke	Required	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Floor wise	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm	130 mm	MR
	2) Number of hydrants per floor	03	03	MR
	3) Hose box	02	02	MR
12.	Yard Hydrants			
	1) Total number of hydrants	07	07	MR
	2) Hose box	07	07	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	4500 LPM	4500 LPM	MR
	b) Head of main pump	70 mtr.	70 mtr.	MR
	c) Number of main pump	02	02	MR
	d) Jockey pump out put	450 LPM	450 LPM	MR
	e) Jockey pump head	70 mtr.	70 mtr.	MR
	f) Stand by pump output	4500 LPM	4500 LPM	MR
	g) Stand by pump head	70 mtr.	70 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	70 mtr.	70 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	1,00,000 liter.	1,50,000 liter.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR

	d) Over head tank capacity	20,000 ltr.	20,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any: ABC, Co2 & water spray at LPG Bank.			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/2015/457 dated 25/02/2022 have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. No. F6/DFS/MS/NDZ/2019/22 dated 03/01/19 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Rajinder Atwal
22/12/22

Name: - Rajinder Atwal
Designation: - DO (CD)

Signature of the Inspecting Officer

Sh Ravinder Singh
22/12/22

Name: Sh Ravinder Singh
Designation: ADO (CC)

Dy. CFS (MS)
[Signature]

F.T. please.
[Signature]

ADDO (CC)
[Signature]

As approved fire safety certificate
issued and signature please.

Dy. CFS (MS)
[Signature]

[Signature]
23/12

F. Dwivedi

[Signature]
23/12/22