

C-41

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

NEW DELHI-110 001.

No.F.6/DFS/MS/School/2022/SZ /1345

Dated: 21/12/22

**FIRE SAFETY CERTIFICATE**

Certified that the Smt. Sarti Devi Public School, Tajpur Khurd, New Delhi-110071, comprised of ground plus two upper floors was issued FSC by this department vide letter F.6/DFS/MS/School/2019/SZ/1812 Dated 19/09/2019. The School building was re-inspected by the officer concerned of this department on 15/12/2022 in the presence of Sh.Praveen Sharma (Owner) and found that School building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....21/12/22..... at New Delhi.



(SUNIL CHAWDHARY)  
DY.CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:-

1. The Manager,  
Smt. Sarti Devi Public School, Tajpur Khurd, New Delhi-110071.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

1. Name & address of the building : Smt. Sarti Devi Public School, Tajpur Khurd, New Delhi-110071.
2. Building is comprised of : G+2 upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/School/2019/SZ/1812 Dated 19/09/2019
6. Fire Safety direction letter No : NBC of India
7. Date of Inspection : 15/12/2022
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer:  
From the building side : Mr. Parveen Kumar (Manager)
10. Year of Construction : Before 2006
11. Applicant's letter No. : Nil Dated- 28/11/2022

S. No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m.	Provided	MR
	• Gate width	4.5 m	Direct accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 No.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 m	Provided	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 No.	Provided	MR
	e. Width of Corridor	1.50 m	Provided	MR
	f. Door Size	1.0 m	.91 x 2	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	02 nos. each floor	Provided	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	IS I marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	02 Nos.	Provided	MR
	• Length of hose reel hose	30 m	N/A	N/A
	• Nozzle diameter	05 mm	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the Pump	30 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The Shortcomings issued vide letter No.F6/DFS/MS/School/2022/SZ/672 dated 01/11/2022 has been complied.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2019/SZ/1812 Dated 19/09/2019 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*R.K. Yadav*  
19/12/2022

Signature of the Inspecting Officer  
Name- R.K. Yadav  
Designation- A.D.O(JKP)

DO (South West)

*Agro (SF)*

*20/12/22*

*F.S.*

*A DO (JP)*

*FT letter to put up for sign please*

*Dy CPO (SF)*

*R.K. Yadav*  
21/12/2022

*M.S. cell*