



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**


No. F6/DFS/MS/Hospital//2022/NDZ/ 583

Dated: 20/12/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Goyal Hospital & Urology Centre located at E-4/8, Krishna Nagar, Delhi-110051, Comprised of basement, ground plus two upper floors owned/occupied by M/s Goyal Hospital & Urology Centre was issued FSC vide letter No. F.6/DFS/MS/Hospital/2019/NDZ/1710 dated 02/09/2019. The premises was re-inspected by the officers concerned of this department on dated 10/12/2022 in the presence of Mr. Dinesh Pandey (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rule, 2010 and that the building/premises is fit for occupancy class "C" 'Institutional' (Nursing Home) with effect from 20/12/2022 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on..... 20/12/2022at New Delhi by


(S.K. DUA)

o/c
2.
**DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE**

To,

Sh. Anil Goyal
M/s Goyal Hospital & Urology Centre
E-4/8, Krishna Nagar, Delhi 110051

Copy:-

The Directorate of Health Services
M.O. I/C Nursing Home Cell,
Govt. of NCT of Delhi, F-17, Karkardooma, Delhi-110032

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/23

1. Name & address of the building : Goyal Hospital & Urology Centre,
E-4/8, Krishna Nagar, Delhi 51
2. Building is comprised of : Basement + Ground plus two upper floors
3. Type of Occupancy : Institutional (Hospital Building)
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/MS/Hospital/2019/NDZ/1710 dt 02/09/2019
6. Fire Safety direction letter No : Delhi Fire Service Act,2007 and Rules 2010
7. Date of Inspection : 10/12/2022
8. Name of the Inspecting officers : DO A K Jaiswal & ADO Deepak Kumar
9. Name and designation of officer from the building side : Mr. Dinesh Pandey (Facility Manger)
10. Year of construction : 2001/2009
11. Applicant's letter No : Nil 01/12/2022

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirements	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	6.00 mtr.	15 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02 nos.	02 nos.	MR
	• Basement	02 nos.	02 nos.	MR
	B. Width of Staircases			
	• Upper floor	02 mtr.	2.00 mtr & 1.20 mtr	MR
	• Basement	1.20 mtr.	1.20 mtr & 01 mtr.	MR
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	02 no.	02 no.	MR
	e. Width of Corridor	2.00 mtr	2.00 mtr	MR
	f. Door Size	02 mtr.	2.00 mtr & 1.00 mtr	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Provided	MR
	• Upper floor	Required	Provided	MR
05.	Fire Extinguishers.			
	• Total numbers	20 nos.	20 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

N/24.

06	First-Aid-Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 No.	02 No.	MR
		30 mtr.	30 mtr.	MR
		05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power Hooter's location 	Smoke & Heat	Smoke & Heat	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
08	MOEFA			
		Required	Provided	MR
09	Public Address System.			
		Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement upper floor sprinkler above false ceiling 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose box 	100 mm	100 mm	MR
		02 no.	02 no.	MR
		02 no.	02 no.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose box 	01 no.	01 no.	MR
		01 no.	01 no.	MR
13	Pumping Arrangements.			
	➤ Ground Level			
	<ul style="list-style-type: none"> Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	➤ Terrace Level			
	<ul style="list-style-type: none"> Discharge of pump Head of the pump Power supply Auto starting of pump 	1620 lpm	1620 lpm	MR
		60 M	60 M	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		50,000 Ltr.	50,000 Ltr	MR
15	Exit Signage.			
		Required	Provided	MR

(Handwritten signature)

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if Any:	N/A	N/A	N/A

Shortcomings communicated Letter no. F.6/DFS/MS/Hospital/2022/NDZ/2587 dated 14/10/2022 has been rectified (undertaking and photocopy enclosed)

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. The FSC issued vide letter No. F.6/DFS/MS/Hospital/2019/NDZ/1710 dated 02/09/2019 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

A.K. Jaiswal
12/12/2022

Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : DO (ED)

Deepak Kumar
12/12/2022

Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : ADO (Shd)

F.T. please.

Dy. CFO (NDZ)

Kimp
15/12

ADO (Shd.)

Sir,
your kind signature pl.
F.T. letter is put up for

Dy. CFO (NDZ)

F.P. wing

Kimp
29/12/22

Deepak Kumar
19/12/2022