

4/26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No.F.6/DFS/MS/EH/SZ/2022/ 360

Dated. 26 / 12 / 2022

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of **M/s Pirates of Grill Shop No T-312-313, 3rd Floor**, Ambience Mall, Plot No 2, Nelson Mandela Marg, New Delhi 110070 in the building Comprised of 03 Basements, Ground Plus Three Upper Floors, owned/occupied by A Unit of Holy Something Restaurant LLP was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/EH/2019/SZ/2340 Dated 19/12/2019. The restaurant premise was re-inspected by the officer concerned of this department on 19/12/2022 in the presence of Mr. Prateek Sagar and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building" (Restaurant running at 3rd Floor)** as above with effect from 26 / 12 / 2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26 / 12 / 2022 at New Delhi by



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi- 110016.
(Ref. MHA Portal ID 2022111620264 dated 02/12/2022)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

M/S



INSPECTION REPORT

1	Name & Address of the Building	M/s Pirates of Grill (A Unit of Holy Something Restaurant LLP) Shop No T-312-313, 3 rd Floor, Ambience Mall, Plot No 2, Nelson Mandela Marg, New Delhi 110070.		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Three tier Basement, Ground + 03 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/2019/SZ/2340 Dated 19/12/2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	19/12/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Prateek Sagar		
10	Year of construction	2010	Restaurant running at 3 rd Floor in Ambience Mall building.	
11	Applicant letter No.	MHA Portal ID 202211620264 dated 02/12/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / BBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building. FSC No.F.6/DFS/MS/Mall/2020/SZ/56 Dated 21/01/2020 of Ambience Mall			
	Road width	Restaurant within Mall	As above	MR
	Gate width		As above	N/A
	Width of internal road		As above	N/A
2	Number, width, type and arrangements of exits.			
	Number of Staircase	Provided & Maintained by Ambience Mall		
	Upper floors	02 Nos	Provided*	MR
	Basement floor	N/A	As above	N/A
	Width of Staircase	Provided & Maintained by Ambience Mall		
	Upper floors	Required	Provided*	MR
	Basement floor	N/A	As above	N/A
	Protection of exits	Provided & Maintained by Ambience Mall		
	Fire check door	Required	Provided*	MR
	Pressurization	N/A	As above	N/A
	No. of continuous staircase to terrace	Required	Provided*	MR
	Width of corridor	N/A	N/A	N/A
	Door size	2 exits	2 m & 1 m	MR
3	Compartmentation.	Provided & Maintained by Ambience Mall		
	Fire check door.	Required	Provided*	MR
	Sealing of electrical shafts.	N/A	As above	N/A
	Fire rating of shaft door.	N/A	N/A	N/A
	Water curtain	N/A	N/A	N/A
	Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.	Provided & Maintained by Ambience Mall		
	Basement	N/A	As above	N/A
	Upper floors	Required	Exhaust fans provided	MR
5.	Fire Extinguishers.			
	Total numbers	05 Nos	06 Nos.	MR
	Types		ABC-04, W.CO ₂ -02	MR

	ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.	Provided & Maintained by Ambience Mall		
	Total numbers on each floor.	Hose Reel	One in Restaurant	MR
	Length of hose-reel hose.		30m	MR
	Nozzle Diameter		5mm	MR
7	Automatic Fire Detection and Alarming system. (Provided & Maintained by Ambience Mall)			
	Type of detectors	Required	Smoke & Heat	MR
	Location of Main Panel	Required	Provided*	MR
	Location of Repeater Panel	N/A	N/A	N/A
	Alternate source of power	Required	Provided*	MR
	Hooter's location	Required	Provided*	MR
8.	MOEFA	Required	Provided*	MR
9.	Public Address System	Required	Provided*	MR
10.	Automatic Sprinkler System	Provided & Maintained by Ambience Mall		
	Basement	Required	Provided*	MR
	Upper floors	Required	Provided in Restt.	MR
	Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.	Provided & Maintained by Ambience Mall		
	Size of Riser/Down-comer	Required	Provided*	MR
	Number of Hydrant per floor	Required	Provided*	MR
	Hose box.	Required	Provided*	MR
12.	Yard Hydrants.	Provided & Maintained by Ambience Mall		
	Total number of hydrants.	N/A	As above	N/A
	2. Hose box.	N/A	As above	N/A
13.	Pumping arrangements.	Provided & Maintained by Ambience Mall		
	Ground Level	Provided & Maintained by Ambience Mall		
	Discharge of main pump.	4500 LPM	Provided*	MR
	Head of main pump.	70 mtr	Provided*	MR
	Number of main pumps.	Two	Provided*	MR
	Jockey Pump output.	450 LPM	Provided*	MR
	Jockey Pump head.	70 mtr	Provided*	MR
	Standby Pump output.	4500 LPM	Provided*	MR
	Standby Pump head.	70 mtr	Provided*	MR
	Auto Starting / Manual Stopping.	Required	Provided*	MR
	Access to pump house	Required	Provided*	MR
	Terrace Level	Provided & Maintained by Ambience Mall		
	Discharge of pump.	N/A	N/A	N/A
	Head of pump.	N/A	N/A	N/A
	Power supply.	N/A	N/A	N/A
	Auto starting of pump.	N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.	Provided & Maintained by Ambience Mall		
	Underground tank capacity.	5,00,000 Ltr	Provided*	MR
	Draw-off connection.	Required	Provided*	MR
	Fire Service Inlet.	Required	Provided*	MR
	Access to tank.	Required	Provided*	MR
	Overhead tank capacity.	20,000 Ltr	Provided*	MR
15.	Exit Signage.	Required	Provided*	MR
16.	Provision of Lifts.	Provided & Maintained by Ambience Mall		
	Pressurization of lift shaft.	N/A	N/A	N/A
	Pressurization of lift lobby.	N/A	N/A	N/A

N/2

	Communication in lift car.	N/A	N/A	N/A
	Fireman's switch.	N/A	N/A	N/A
	Lift signage.	N/A	N/A	N/A
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19.	Fire Control Room.	Provided & Maintained by Ambience Mall		
	Detector System Panel.	N/A	As above	N/A
	Flow Switch Panel.			
	PA system Panel.	N/A	As above	N/A
	Battery backup	N/A	As above	N/A
	Building floor plan	N/A	As above	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any :	N/A	As above	N/A

Note :-*Fire safety arrangements Provided & Maintained by Ambience Mall

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/EH/2019/SZ/2340 Dated 19/12/2019 , renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer

Name: Rajesh Kumar

Designation: ADO / BCP

DO (SD)

msl
19/12

Defo/s2

Sh

F. 7.

ADO/STF

As approved, F.T. letter is put up
for your signature pl

1/14
2012

Defo/s2

Sh

M. S. Ull