

C 41

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/School/1355

Dated: 27/12/2022

FIRE SAFETY CERTIFICATE

Certified that the building of Kendriya Vidhalaya Located at Sector – 08, SPG Complex, Dwarka, New Delhi 110077 comprised of Ground + 03 Upper Floors was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2019/SZ/1587 Dated 09/08/2019. The premises was re- inspected by the officer concerned of this department on 15/12/2022 in the presence of Sh. Mragendra Shrivastav (Vice Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service 2010, and that the premises is fit for occupancy class-B “Educational” with effect from 27/12/22 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...27/12/22...at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. The Principal Kendriya Vidhalaya Located at Sector – 08, SPG Complex, Dwarka, New Delhi 110077.
2. Directorate of Education Old Secretariat Delhi – 110054.
3. The Assistant Engineer (E) , Delhi Electrical Division -51, CPWD, Sub – Division – III, RHTC, Najafgarh, New Delhi – 110043.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

Re inspection to see the compliance of shortcomings communicated vide letter dated 20/06/2022

INSPECTION REPORT

1. Name & address of the building: Kendriya Vidhalaya Located at Sector – 08, SPG Complex, Dwarka, New Delhi 110077.
2. Type of Occupancy : Educational Ground + 3 Upper Floor
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2019/SZ/1587, dated 09/08/19
5. Fire Safety directives Letter No. : Old case
6. Date of inspection : 15/12/2022
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Mragendra Shrivastav (V. Principal)
9. Year of Construction : 2015
10. Applicant's letter No. : 34(20)/A/E(E)-III/RHTC-51/2022-23/160, dated 28/11/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/12, N/13 & N/14	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	06 M	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 Nos.	03 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided	MR(being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02 Nos.	Provided	MR
	e. Width Of Corridor	1.5 mtr	Provided	MR
	f. Door Size	1 mtr	Old case	MR(Being old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

(Signature)

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		12 a/c charge	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 nos. each floor ABC & CO ₂ ISI marked	21 Nos. ABC & CO ₂ Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 Nos.	Provided	MR
		30 m	Provided	MR
		5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		2 X 450 lpm	Provided	MR
		35 Mtr	Provided	MR
		Required	DG Set	MR
		Required	Provided	MR

10

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltr	10,000Ltr	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2019/SZ/1587, dated 09/08/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name *Uday Vik Singh*
Designation *ADD/DWR*

D/S *at 19/12/22*

Dycho (S2)

ADD (DWR)

F.T.
sh