



C-17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/EH/2022/NDZ/ 361

Dated: 26/12/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s KFC Restaurant, (Sapphire Food India Ltd.) located at Shop No. 6, Ground Floor, Dilshad Garden Metro Station, Delhi-110095, in a building comprising Ground, concourse level & platform level, owned / occupied by Sapphire Foods India Pvt. Ltd., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 24/09/2022 in the presence of Sh. Moni (Manager) and found that the building / premises is fit for the occupancy class "Assembly" (Group-D) / **Eating House** with effect from 26/12/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/12/2022 at New Delhi by.


(ATUL GARG)
DIRECTOR

o/c
2
DELHI FIRE SERVICE

Copy to:-

1. M/s KFC Restaurant (Sapphire Food India Ltd.) Shop No. 6, Ground Floor, Dilshad Garden Metro Station, Delhi-110095
2. The Joint Commissioner of Police (Lic.), 1st floor Police Station Defence Colony, New Delhi
MHA ID No. 2022082916749 Dated 30/08/2022

Conditions for the validity of Fire Safety Certificate


1. All the fire safety arrangements provided therein shall be maintained in good working conditions all the time.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. All the means of escape shall be kept free of all type of obstruction all the time.
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

N/1

INSPECTION REPORT

1. Name & address of the building : KFC Restaurants, (Sapphire Foods India Ltd.)
Shop No. 6, Ground Floor, Dilshad Garden Metro Station, Delhi-110095.
2. Building is comprised of :Ground, concourse level & platform level
(Restaurant on Ground Floor only)
3. Type of Occupancy :Restaurant (Assembly)
4. Type of Case :New
5. Details of Previous NOC letter :Nil
6. Fire Safety directive letter No :NBC part IV
7. Date of Inspection :24/09/2022
8. Name of the Inspecting officers :ADO Deepak Kumar D.O. A.K. Jaiswal
9. Name and designation of Officer from the building side :Mr. Moni (Manager)
10. Year of Construction :
11. Applicant's letter No :2022082916749, Dated- 30/08/2022

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	12mtr.	28 mtr.	MR
	• Gate width	4.5 mtr.	06 mtr.	MR
	• Width of internal road	06 mtr.	06 mtr.	MR
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.50 mtr.	1.90 & 1.50 mtr.	MR
	g. No. of Continuous Staircase	N/A	N/A	N/A
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Provided	MR
05.	Fire Extinguishers			
	• Total numbers	03nos.	05 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

2. 

06	First-Aid-Hose Reels	Provided & maintained by Metro station		
	Total numbers	01 nos	01 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System			
	• Type of detectors	N/A	Smoke/Heat	N/A
	• Location of main panel	N/A	Provided	N/A
	• Location of repeater panel	N/A	Provided	N/A
	• Alternate source of power	N/A	Provided	N/A
	• Hooter	Near Gate	Provided	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	Provided	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	Provided & maintained by Metro station		
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 nos.	01 nos.	MR
	• Hose box	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level	Provided & maintained by Metro station		
	• Discharge of main pump	1800 lpm	Provided	MR
	• Head of main pump	70 mtrs	Provided	MR
	• Number of main pumps	02 nos	Provided	MR
	• Jockey pump out put	180 lpm	Provided	MR
	• Jockey pump head	70 mtr	Provided	MR
	• Standby pump out put	1800 lpm	Provided	MR
	• Standby pump head	70 mtr	Provided	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting	Common with Metro Station		
	• Underground tank capacity	50,000 ltrs	2,00,000 ltrs	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	20,000 Ltrs.	20,000 Ltrs.	MR
5	Exit Signage.	Required	Provided	MR

2.

16	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of lift shaft Pressurization of lift lobby Communication in lift car Firemen's grounding switch Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector system panel Flow switch panel PA system panel Battery backup Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection and fire fighting system is common with metro station.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule, grant of fire safety certificate under rule 35 of the Delhi Fire Service Rule, 2010 is recommended please.

Deepak
26/09/2022
Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : ADO (Shd)

A.K. Jaiswal
26/09/2022
Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : DO (ED)

Dy. CFO (NDZ) *Please spec about mezzanine area shown in the plans uploaded with application.*

DO (ED) + ADO (Shd.)

div P
28/09/22

There is a small mezzanine floor in this E/H. FSC is recommended for ground floor only. This mezzanine floor is being used as storage purpose.

Dy. CFO (NDZ)

Approved
3/10/22

C.F.O. *Khushi*
4/10/2022

div P
04/10/22

9+ mem 15 part of this case he