

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6 DFS MS IndL/SZ/2022/591

Dated: 27/12/2022

FIRE SAFETY CERTIFICATE

Certified that the **Maruti Suzuki India Limited** Workshop/Sales building located at C-119, Naraina Industrial Area, Phase-1, New Delhi- 110028, comprised of Basement, Ground plus one upper floors was issued No Objection Certificate by this department vide letter No. F.6 DFS MS 2007/3747 dated 18.12.2007. The Premises was re-inspected by the officers concerned of this department on 22.12.2022 in presence of Sh Ramanand Yadav (Caretaker), and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi fire service Rules 2010 and that the building premises is fit for occupancy **class Group G (Industrial Building)** with effect from 27/12/2022 for a period of **03 (three)** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 27/12/2022 at New Delhi by.



(**Sunil Chaudhary**)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to:-

1. The Authorized Signatory, M/s. Maruti Suzuki India Limited, C-119, Naraina Industrial Area, Phase- 1, New Delhi- 110028.
2. The Executive Engineer (Building), MCD, Karol Bagh Zone, Anand Parbat, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBI.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.delhigovt.nic.in.

2/10

INSPECTION REPORT

1. Name & address of the building : Maruti Sales & Service Delhi, located at C-119, Naraina Industrial Area, Phase-1, New Delhi- 110028.
2. Type of Occupancy : Industrial
3. Building Composition : Said building comprised of basement, ground plus one upper floor
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/2007/3747 dated 18.12.2007
6. Fire Safety directives letter No : F.6/DFS/MS/BP/2004/637 dated 23.03.2004
7. Date of inspection : 22.12.2022
8. Name of the Inspecting Officers : Vedpal Chhikara, DO (SW) & P.V. Rathee, ADO (SRD)
9. Name and designation of officers from the building side : Sh. Ramanand Yadav (Caretaker)
9. Year of Construction : Before 2004
10. Applicant's letter No. : Letter No. nil, dated 09.12.2022

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Requirement as per NOC dated 18.12.2007 | Provided at site | Remarks MR/NMR |
|--------|---|---|--|----------------|
| 1 | Access to building | | | |
| | • Road width | 06 mts | Provided | MR |
| | • Gate width | 4.5 mts | Provided | MR |
| | • Width of internal road | N/A | N/A | N/A |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | - | - | - |
| | • Upper Floors | 05 +01 ramp | 05 +01 ramp | MR |
| | • Basements | 04 +02 ramp | 04 +02 ramp | MR |
| | b. Width of staircases | - | - | - |
| | • Upper Floors | 1.25 mts. each | 4 staircase - 1.25 mts each, 1 staircase- 1.30 mts from ground floor to terrace (iron made) & 1 ramp- 3.50 mts | MR, old case |
| | • Basements | 1.25 mts. each | 04 staircase- 1.25 mts each & 02 ramp- 3.25 & 3.50 mts | MR, old case |
| | c. Protection of exits | - | - | - |
| | • Fire check door | Required | Provided | MR |
| | • Pressurization | N/A | N/A | N/A |
| | e. No. of continuous staircases to terrace | 05 | 04 (basement to terrace) & 01 (ground floor to terrace) | MR, old case |
| | g. Width of Corridor | N/A | N/A | N/A |
| | h. Door Size | 1.50 mts | Provided | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire Rating of shaft door | N/A | N/A | N/A |
| | • Water Curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 4 | Smoke Management System. | | | |
| | • Basements | 30 a/c per hour | Exhaust fan provided | MR |
| | • Upper floors | 12 a/c per hour | Exhaust fan provided | MR |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 28 | Provided | MR |
| | • Types | ABC type | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |

✓

| | | | | |
|----|--|-------------|----------------------|------|
| 9 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | 02 | Provided | MR |
| | • Length of hose reel hose | 30 m | Provided | MR |
| | • Nozzle diameter | 5 mm | Provided | MR |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | Smoke heat | Provided | MR |
| | • Location of Main Panel | Required | Provided in basement | MR |
| | • Location of Repeater Panel | Required | Provided | MR |
| | • Alternate source of power | Required | Provided | MR |
| | • Hooters' Location | Required | Provided at workshop | MR |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System. | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | Required | Provided | MR |
| | • Upper Floor | Required | Provided | MR |
| | • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | • Size of riser down-comer | 150 mm | Provided | MR |
| | • Number of hydrants per floor | 02 | Provided | MR |
| | • Hose Box | 02 | Provided | MR |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N/A | 04 | N/A |
| | • Hose Box | N/A | 04 | N/A |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | --- | --- | --- |
| | ➤ Discharge of main Pump | 2850 LPM | Provided | MR |
| | ➤ Head of Main pump | 60 mts | Provided | MR |
| | ➤ Number of main pumps | 01 | Provided | MR |
| | ➤ Jockey Pump out put | 180 LPM | Provided | MR |
| | ➤ Jockey pump head | 60 mts | Provided | MR |
| | ➤ Standby Pump out put | 2850 LPM | Provided | MR |
| | ➤ Standby Pump Head | 60 mts each | Provided | MR |
| | ➤ Auto Starting Manual stopping | Required | Provided | MR |
| | ➤ Pump House Access | Required | Provided | MR |
| | • Terrace level | ----- | ----- | ---- |
| | ➤ Discharge of pump | 450 LPM | 450 LPM | MR |
| | ➤ Head of the pump | 40 mts | 40 mts | MR |
| | ➤ Power Supply | Required | Provided | MR |
| | ➤ Auto Starting of pump | Required | Provided | MR |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | 50.000 Its | 1.00000 Its | MR |
| | ➤ Draw-off connection | Required | Provided | MR |
| | ➤ Fire service inlet | Required | Provided | MR |
| | ➤ Access to tank | Required | Provided | MR |
| | • Overhead Tank capacity | 30.000 Its | Provided(30.000 Its) | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |

| | | | | |
|----|--|----------|---|-----|
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | Required | Provided | MR |
| | • Fireman's Grounding Switch | Required | Provided | MR |
| | • Lift Signage | Required | Provided | MR |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | Required | Two ABC type fire extinguisher found provided near elect. panel | MR |

The fire protection systems provided in the building were test checked at random and found satisfactory at the time of inspection. *The shortcomings issued vide letter dt 2-11-22 found Complied.*

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, the NOC issued vide letter No. F.6/DFS/MS/2007/3747 dated 18.12.2007, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval & signature please.

[Handwritten Signature]
20/12/22

[Handwritten Signature]
22/12/22

Signature of the Inspecting Officer
Name- Vedpal Chhikara
Divisional Officer (SW)

Signature of the Inspecting Officer
Name- P.V. Rathee Divisional
Asstt. Div. Officer (S.Rd)

[Handwritten Signature]
DY. CFO (S2)

[Handwritten Signature]
A.D.O (S.Rd)

F.T. Letter is put up for sign. please

[Handwritten Signature]
DY. CFO (S2)

[Handwritten Signature]
M.S. Ull