

C-25

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2022/SZ/ 1349

Dated: 23/12/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Shanti Gyan Vidyapeeth School**, Goyla (Dwarka), Near Sector-19, New Delhi-110071, comprised of ground plus three upper floors, owned/occupied by Shanti Gyan Vidyapeeth School was issued Fire Safety Certificate by this department vide letter no. **F.6/DFS/MS/School/2019/SZ/2179 dated 19/11/2019**. The School building was re-inspected by the officer concerned of this department on 20/12/2022 in the presence of **Sh. Rohit Kumar Khurana (Manager)** and found that School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational" for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on. 23/12/2022

at New Delhi



(SUNIL CHAWDHARY)  
DY.CHIEF FIRE OFFICER  
DELHI FIRE SERVICE



Copy to:-

1. The Manager, Shanti Gyan Vidyapeeth School, Goyla (Dwarka), Near Sector-19, New Delhi-110071.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/15

**INSPECTION REPORT**

Name & address of the building : Shanti Gyan Vidyapeeth School, Goyla (Dwarka), Near Sector-19, New Delhi-110071.  
 building comprised of : Ground plus three upper floors.  
 Type of Occupancy : Educational  
 Type of Case : Renewal  
 Details of Previous NOC : F.6/DFS/MS/School/2019/SZ/2179 dated 19/11/2019  
 Fire Safety directives letter No : NBC Part-IV  
 Date of inspection : 20/12/2022  
 Name of Inspecting Officer : A.D.O. R.K.Yadav  
 Name and designation of officers :  
 From the building side : Sh. Rohit Khurana (Manager)  
 10. Year of Construction : 2009/2014/2019  
 11. Applicant's letter No. : Nil dated 05/12/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	06 m 4.5 m N/A	06 m 4.5 M N/A	MR MR N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	02 No.'s N/A	02 No.'s N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	1.50 m N/A	1.5 m each N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Two	M/R
	e. Width of Corridor	1.50 m	1.75m Provided	M/R
	f. Door Size	12.0 m	1.20 m	M/R
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	N/A Required	N/A Natural ventilation provided	N/A M/R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	02 no's/floor ABC/CO <sub>2</sub> type ISI marked	Provided Provided Provided	M/R M/R M/R

17/16

6.	<b>First-Aid Hose Reels</b>	One	Provided	M/R
	• Total numbers on each floor	30 m	Provided	M/R
	• Length of hose reel hose	5 mm	Provided	M/R
	• Nozzle diameter			
7.	<b>Automatic fire detection and alarming system</b>	N/A	N/A	N/A
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>	100 mm	100 mm	MR
	• Size of riser/down-comer	One	One	MR
	• Number of hydrants per floor	One	One	MR
	• Hose Box			
12.	<b>Yard Hydrants</b>	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box			
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	30 m	Provided	M/R
➤ Power Supply	Required	Provided	MR	
➤ Auto Starting of pump	Required	Provided	MR	
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR

✓

N/17



M/R	Provision of Lifts.	No Lift		
M/R	• Pressurization of Lift Shaft	N/A	N/A	N/A
M/R	• Pressurization of Lift lobby	N/A	N/A	N/A
N/A	• Communication In lift Car	N/A	N/A	N/A
N/A	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	<b>Standby power supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2019/SZ/2179 dated 19/11/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

  
 Signature of Inspecting Officer  
 Name:- R.K.Yadav  
 Designation:- Asstt. Divisional Officer

DO(South West)

  
 22/12/22  
  
 ADO V K A