

C-7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / WZ / 2022 / College/23

Dated 01/12/2022

FIRE SAFETY CERTIFICATE

Certified that the **Sushila School of Nursing** located at **Gali No. 9, Gautam Colony, Safiabad Road, Narela, Delhi-110040** comprised of **Two Blocks (01 Block- Ground + Two upper floors & 01 Block-Ground+Three upper floors)** owned/ occupied by **Sushila School of Nursing** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on **15.11.2022** in the presence of **Sh. Ajit Singh Khatri (Director)** and found that the building/ premises is fit for occupancy '**Educational**' with effect from 01/12/2022 for a period of **03 (Three) years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on01.12.2022..... at New Delhi by


(Ajit Singh Khatri)
Director

Ph-011-23414000
ole R

Copy to:-

1. Sushila School of Nursing, Gali No. 9, Gautam Colony, Safiabad Road, Narela, Delhi-40.
2. Dy. Health Officer, Civil Line Zone, 16 Rajpura Road, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Sushila School of Nursing located at Gali No. 9, Gautam Colony, Safiabad Road, Narela, Delhi-40
2. Type of Occupancy : Educational
3. Building Composition : Two Blocks Interconnected (01 Block-Ground+ Two Upper floors & 01 Block- Ground+ Three Upper floors)
4. Type of Case : New Case
5. Details of Previous NOC : NIL
6. Fire Safety directives letter No : Nil
7. Date of inspection : 15/11/2022
8. Name of Inspecting Officer : ADO(BW)
9. Name and designation of officers from the building side : Sh. Ajit Singh Khatri (Director)
10. Year of Construction : ---
11. Applicant's letter No. : F.5(1)(1)/DNC/2002/590-592 Dated 20/09/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m each	1.70 m, 1.50 m & 1.30 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	03	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1.2m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	12 ac/hr	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	Required	25 nos	MR
	• Types	ABC	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System	NA	NA	NA
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants	NA	NA	NA
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants	NA	NA	NA
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	---	---	---
		---	---	---
		900 lpm	Provided	MR
		40 m	40 m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltrs	10,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel 	NA	NA	NA
		NA	NA	NA

22/11/20

2/14

• PA System Panel	NA	NA	NA
• Battery backup	NA	NA	NA
• Building Floor Plans	NA	NA	NA
Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to Grant Fire Safety Certificate under Rule 35 of Delhi Fire Service Rules, 2010.

[Signature]
 ADO(BW)
 17/11/22
 Signature of Inspecting Officer
 Name: Rajeev Kumar Sinha
 Designation; ADO(BW)

DO (S.W) *[Signature]*
 18/11/22

Dy. CEO (W2) *[Signature]*
 18/11/22

CFP *[Signature]*
 20/11/2022

Director *[Signature]*
 29/11/22

ADCP *[Signature]* / BW

Sir, F-T letter is put up for signature
[Signature]
 ADO(BW)
 30/11/22

Director (D&S) *[Signature]*
 21/11/22