

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/2022/ 596

Dated : 30.12.2022

FIRE SAFETY CERTIFICATE

Certified that the **Talkatora Indoor Stadium** located at **New Delhi** is comprised of **02B + Ground floor**. The FSC was earlier granted by this department vide letter **F6/DFS/MS/2020/STDM/44** dated **16/01/2020** for **stadium only (except annexe building)**. Now, the premises was re-inspected by the officer concerned of this department on **20/12/2022** in the presence of **Sh. Mahender Shokeen (Fire Officer), Sh. Vinod Meena, AE & Sh. Jatin Arora, JE, NDMC** and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building (Group D) for Talkatora Indoor Stadium** with effect from **30.12.2022** for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued. 30.12.2022 at New Delhi by.


(S. K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Chief Architect, Department of Architecture and Environs, New Delhi Municipal Council, Palika Kendra, New Delhi.
2. Sh. N.K. Gaur, Fire Officer, New Delhi Municipal Council, Palika Kendra, New Delhi.
3. The Executive Engineer, Talkatora Stadium, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

N136
INSPECTION REPORT

1. Name & address of the building : **Talkatora Indoor Stadium , New Delhi**
2. Type of occupancy : **Assembly Building B + Ground Floors (Except Annexe Building)**
3. Type of case:- : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/2020/STDM/44 dated 16/01/2020**
5. Fire safety directives No. : **F6/DFS/MS/NDZ/2020 /44 dated 16/01/2020**
6. Date of inspection:- : **20/12/2022**
7. Name of the inspecting officer : **Sh. Rajinder Atwal (DO/CD) & Sh. Ravinder Singh (ADO/CC)**
8. Name & designation of officer : **Sh. Mahender Shokeen (Fire Officer),
From the building side Sh. V. Meena , AE & Sh. Jatin Arora , JE , NDMC**
9. Year of construction : **2007**
10. Applicant's letter No : **Mail id fo@ndmc.gov.in dated 15.11.2022**

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	13 mtr.	30 mtr.	MR
	2) Gate width	06 mtr.	06 mtr.	MR
	3) Width of internal road	06 mtr.	06 mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	03	03	MR
	2. Basements	09	09	MR
	B. Width of staircase			
	1. Upper floors	1.5 Mtr.	1.5 mtr. each	MR
	2. Basements	1.5 mtr. & 02 ramp	1.5 mtr. each & 02 ramp	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
		01 No	01 No	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 Mtr.	1 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	100 Nos.	101 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 &	MR

✓

	3) ISI marking	Required	W.CO2 Provided	MR
6.	First-Aid Hose Reel			
	1) Total number	20 nos .	/20 nos .	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	05 mm	05 mm.	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Ground floor	Provided	MR
	3) Location of repeater panel	Required	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	At each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm	150 mm	MR
	2) Total Number of hydrants	20 nos .	20 nos .	MR
	3) Hose box per floor	20 nos .	20 nos .	MR
12.	Yard Hydrants			
	1) Total number of hydrants	08	08	MR
	2) Hose box	08	08	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280 LPM	2280 LPM	MR
	b) Head of main pump	70 mtr.	70 mtr.	MR
	c) Number of main pump	02	02	MR
	d) Jockey pump out put	220 LPM	220 LPM	MR
	e) Jockey pump head	70 mtr.	70 mtr.	MR
	f) Stand by pump output	2280LPM	280LPM	MR
	g) Stand by pump head	70 mtr.	70 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	900 LPM	900 LPM	MR
	b) Head of pump	40 mtr	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	2,00,000 ltr.	2,00,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR



N/38

	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 Ltr.	20,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. : F6/DFS/MS/2020/STDM/44 dated 16/01/2020, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended for approval .

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Sh. Rajinder Atwal
27/12/22

Ravinder Singh
27/12/22

Name :- Sh. Rajinder Atwal
Designation :- DO (CD)

Name :- Ravinder Singh
Designation :- ADO (CC)

Dy. Insp. Chand

F.T. please.

Ravinder Singh
28/12

ADP (CC)

As approved, F.T. setup for the period and
Signature please.

Dy. Insp. Chand

Ravinder Singh
29/12/22

F.P. wing

Ravinder Singh
25/12/22