

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/EH/NDZ/2022/ 365

Dated: 29/12/2022

FIRE SAFETY CERTIFICATE

Certified that M/s The Funny Boy is situated at 2213 A, Chuna Mandi, Pahar Ganj, New Delhi. The building is comprised of ground and four upper floor and restaurant at ground, first floor & second floor and staff rooms at 3rd & 4th floor. The premises was inspected by officer concerned of this department on 16/12/22 in the presence of Mr. Amit (Care taker) and found that the said restaurant has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Occupancy (Group- D) for Restaurant at ground, first floor & second floor only** with effect from 29/12/22.....for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 29/12/22 at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi: to kindly ensure the occupancy as detailed above and take n/a in r/o deviation if any.
2. The Addl. Commissioner of Police (Lic), Ist floor, PS Defence Colony, New Delhi Online ID No. 2022110119775 dated 14/12/2022.
3. The Manager, M/s The Funny Boy, 2213 A, Chuna Mandi, Pahar Ganj, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. This FSC is valid for restaurant at ground, first and second floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
10. Any flammable material for interior decoration shall strictly prohibited.

N/2

INSPECTION REPORT

1. Name & address of the building : M/s The Funny Boy 2213- A, Chuna Mandi, Paharganj, New Delhi.
Ground and four upper floors.
2. Type of occupancy: - : Mixed Occupancy
Restaurant at ground to second and residential at 3rd and 4th floor
3. Type of case:- : New
4. Details of previous FSC:- :N/A
5. Fire safety directives No.- :N/A
6. Date of inspection:- :16/12/22
7. Name of the inspecting officer:- : Sh. Rajinder Atwal (DO/CD) & :Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer from the building side:- : Mr. Amit care taker
9. Year of construction:- :2020
10. Applicant's letter No:- : ID No. 2022110119775 dated 14/12/2022.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirements as per UBBL-2016/NBC part-4	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr	Provided	MR
	2) Gate width	N/A	Directly approach from road	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 nos	02 nos	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 meter	1.5 meter	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	Provided	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02 nos	Provided	Provided
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2x1.5 mtr.	Provided	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR



6.	First-Aid Hose Reel			
	1) Total number of each floor	01	Provided	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	Provided	N/A
	2) Location of main panel	N/A	Ground floor	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	Provided	N/A
	5) Hooter's Location	N/A	At each floor	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	Provided	MR
	2) Number of hydrants per floor	01	01 nos	MR
	3) Hose box	01	01nos	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 lpm	450 LPM Provided	MR
	b) Head of pump	30 mtr.	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	N/A	N/A	N/A

M4

	capacity			
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000 liter	20,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and Found functional at the time of inspection. Further, the applicant has applied on online portal for ground, first and second upper for restaurant (assembly) and third & fourth floor for staff room (residential)

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, if agreed, we may issue Fire Safety Certificate (FSC) to said building. Accordingly, reply letter is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer

[Handwritten Signature]
19/12/22

Name: - Rajinder Atwal
Designation: - DO (CD)

Signature of the Inspecting Officer

[Handwritten Signature]
19/12/22

Name: - Ravinder Singh
Designation: - ADO (CC)

[Handwritten Signature]
Dy. C.F.O. (CD)

[Handwritten Signature]
20/12/22

C.F.O.
[Handwritten Signature]
22/12/2022

[Handwritten Signature]
22/12/22

DO (CD)

G+4 are covered under OFS Act, Issue notice to building by 22/12/22 put up letter High vada.

[Handwritten Signature]
22/12/22