

C-31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2022 / School / W / 1351



Dated: 26/12/2022

FIRE SAFETY CERTIFICATE

Certified that the **Venus Public School** located at **Main Qutabgarh Road, Kanjhawala, Delhi-110081** comprised of two blocks (Ground plus One upper floor and Ground Floor only) owned/occupied by **Venus Public School**. The premise was inspected by the officer concerned of this department on 09.12.2022 in the presence of Smt. Ridhima (In-charge) and observed that the fire safety measures are in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi have deemed complied and that the building is fit for occupancy class B "Educational building" with effect from ...26/12/2022... for a period of **three years**, subject to the conditions as mentioned below.

Issued on ...26/12/2022... at New Delhi

Yours faithfully


(Atul Garg)
Director


Copy to :-

1. The Director, Education, Old Secretariat, Delhi.
2. The Principal, Venus Public School, Main Qutabgarh road, Kanjhawala, Delhi-81.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on

WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building :	Venus Public School, Main Qutabgarh Road ,Kanjhawala, Delhi-110081	(Previous - Ground Floor Only)
2. Type of Occupancy	Educational	
3. Building Comprised	Two Blocks (01- Ground Floor & 01-Ground + One upper floor)	
4. Type of Case	Renewal (Addition/Alteration)	
5. Details of Previous NOC	F6/DFS/MS/2017/School/WZ/678 dated 12/05/2017	
6. Fire Safety directives letter No	Director of education circular dated : 01/03/2011	
7. Date of inspection	09 /12/2022	
8. Name of Inspecting Officer	ADO, R K Sinha	
9. Name and designation of officers From the building side	Smt. Ridhima (In-charge)	
10. Year of Construction	2004 & 2022	
11. Applicant's letter No	E Mail id : Dated-28/11/2022	

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floor	1.50 m	1.50 m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m & 1.20 m (for New Block)	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA

	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	06	06	MR
	<ul style="list-style-type: none"> Types 	ABC	ABC	MR
	<ul style="list-style-type: none"> IS marking 	Yes	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	NA	NA	NA
	<ul style="list-style-type: none"> Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> Nozzle diameter 	NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA			
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System	NA	NA	NA
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Ground Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	NA	NA	NA
		NA	NA	NA

M

	<ul style="list-style-type: none"> ➤ Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> • Terrace level 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Discharge of pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of the pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Power Supply 	-	-	-
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> • Overhead Tank capacity 	NA	NA	NA
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication In lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> • Lift Signage 	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Location 	NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Battery backup 	NA	NA	NA
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

AL

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter no. F6/DFS/MS/2017/School/WZ/678.

~~DO (WZ)~~

~~KJ~~
13/12/2022

~~Dy CFO (WZ)~~

~~[Signature]~~
13/12/2022

~~[Signature]~~
ADO (B.W.)
13/12/22

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

~~CFO~~
~~Kugh~~
14/12/2022

Put up FSC as per performa of the Act.

~~Director~~

~~Dy CFO (WZ)~~

~~[Signature]~~
16/12/22

~~DO (WZ) on mlr.~~

Pr. DIFA New Delhi and resubmitted as per Director of education circular.

~~Dy CFO (WZ)~~

~~[Signature]~~
20/12/22

~~[Signature]~~
21/12/22

~~CFO~~
~~Kugh~~
21/12/2022

ATPL

~~Director~~
~~[Signature]~~
21/12/22

~~ADY BN~~