

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2023 / School / WZ / 04

Dated: 03/01/2023

FIRE SAFETY CERTIFICATE

Certified that the **Tomar Public School** located at **Village Bhorgarh, Delhi-110040** comprised of **Ground and Two upper floors** owned/occupied by **Tomar Public School** was issued FSC by this department vide letter No **F-6/DFS/MS/2019/2292** dated 10.12.2019. The building was inspected by the officer concerned of this department on 26.12.2022 in the presence of Sh. Vinod Kumar Tomar (Manager), and observed that all the fire prevention and fire safety arrangements as provided in the building found in good working condition. The premises have deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy **Group B Educational** with effect from ...03/01/2023. for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..03/01/2023.... at New Delhi, by


(Dharampal Bhardwaj)
Dy. CHIEF FIRE OFFICER
WEST ZONE

Copy to :-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.
2. The Principal, Tomar Public School, Village Bhorgarh, Delhi-40.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Tomar Public School located at Bhorgarh, Delhi-110040.
 2. Type of Occupancy : Educational
 3. Building Comprised : Ground+ Two upper floors
 4. Type of Case : Renewal
 5. Details of Previous NOC : Letter No. F.6/DFS/MS/2019/2292 Dated-10/12/2019
 6. Fire Safety directives letter No : As Per N/7
 7. Date of inspection : 26/12/2022
 8. Name of Inspecting Officer : ADO R.K Sinha
 9. Name and designation of officers
 From the building side : Sh. Vinod Tomar (Manager)
 10. Year of Construction : 2005 & 2011
 11. Applicant's letter No. : T/P/S, Dated-09/12/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	01	02	MR(old case)
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floor	1.50 m	1.25 m & 95cm	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR



5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	05	09	MR
	<ul style="list-style-type: none"> Types 	ABC	ABC	MR
	<ul style="list-style-type: none"> IS marking 	Yes	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Ground Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

NC

MR
MR
N

- Terrace level
- Discharge of pump
- Head of the pump
- Power Supply
- Auto Starting of pump

450 lpm
40 m
Required
Required

450 lpm
40 m
Provided
Provided

MR
MR
MR
MR

14. **Captive Water Storage for fire fighting**

- Underground tank capacity
 - Draw-off connection
 - Fire service inlet
 - Access to tank
- Overhead Tank capacity

NA
NA
NA
NA

NA
NA
NA
NA

NA
NA
NA
NA

10,000 ltrs
Required

10,000 ltrs
Provided

MR
MR

15. **Exit Signage.**

16. **Provision of Lifts.**

- Pressurization of Lift Shaft
- Pressurization of Lift lobby
- Communication In lift Car
- Fireman's Grounding Switch
- Lift Signage

NA
NA
NA
NA
NA
NA

NA
NA
NA
NA
NA
NA

NA
NA
NA
NA
NA
NA

17. **Standby power supply**

18. **Refuge Area.**

- Total Area
- Location

NA
NA

NA
NA

NA
NA

19. **Fire Control Room**

- Detector System Panel
- Flow Switch Panel
- PA System Panel
- Battery backup
- Building Floor Plans

NA
NA
NA
NA
NA

NA
NA
NA
NA
NA

NA
NA
NA
NA
NA

20. **Special Fire Protection System for Protection of special Risks, if any:**

NA

NA

NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended for renewal of Fire Safety Certificate issued vide letter no.F-6/DFS/MS/2019/2292 under rule 35 of the Delhi Fire Service Rules 2010.

~~DO (W2)~~

~~ADDO~~
27/12/2022

~~ADDO (W2)~~

[Handwritten signature]
27/12/22

[Handwritten signature]
ADDO (B10)
27/12/22

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADDO/B.W.

~~ADDO/B10~~ Sir, F-T letter is put up for signature

~~ADDO (W2)~~

[Handwritten signature]
27/12/2022

[Handwritten signature]
ADDO (B10)
29/12/22

msf cell