



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज भी
आज भी


No. F6/DFS/MS/School/2023/ 05

Dated: 03/01/2023

FIRE SAFETY CERTIFICATE

Certified that the **M.C. Primary School** located at **Gali No.09, Wazirabad Village-II, Delhi-110084** comprised of **Single block, Ground & first floor only** owned/occupied by North M.C. **Primary School** have complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no. 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on **26.12.2022** in the presence of **Sh. Vijay Kr. Gupta (Principal)** and that the building/premises is fit for occupancy "**Group B Educational**" with effect from **03.01.2023** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **03.01.2023** at New Delhi


(Aul Gang)
Director
Ph:-011-23414000
ofc

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, M.C. Primary School located at Gali No.09, Wazirabad Village-II, Delhi-84.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M.C Primary School located at Gali No-9, Wazirabad Village, Delhi-110084.
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Composition of building : Single block, Ground & first floor only
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 26.12.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Sh. Vijay Kr. Gupta (Principal)
10. Year of Construction : 1992
11. Applicant's letter No. : Letter No. Nil Dated: 12.12.2021 & DFS Dairy No.9221 Dated:19.12.2022

Sl. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular Dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.5m	4.5m & 2.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.25m	1.25m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1.15m & 80m double door	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	04nos	04nos	MR
	• Types	ABC/Co2	ABC-04	MR
	• ISI marking	ISI Marked	Provided	MR
6	First-Aid Hose Reels.			

Signature

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage.	NA	NA	NA

N/12

N/12
16

16	Provision of Lifts.			N/A	N/A	N/A
	•	Pressurization of Lift Shaft		N/A	N/A	N/A
	•	Pressurization of Lift lobby		N/A	N/A	N/A
	•	Communication In lift Car		N/A	N/A	N/A
	•	Fireman's Grounding Switch		N/A	N/A	N/A
	•	Lift Signage		N/A	N/A	N/A
17	Standby power supply					
18	Refuge Area.			N/A	N/A	N/A
	➤	Total Area		N/A	N/A	N/A
	➤	Location				
19	Fire Control Room			N/A	N/A	N/A
	•	Detector System Panel		N/A	N/A	N/A
	•	Flow Switch Panel		N/A	N/A	N/A
	•	PA System Panel		N/A	N/A	N/A
	•	Batter backup		N/A	N/A	N/A
	•	Building Floor Plans		N/A	N/A	N/A
	•	Special Fire Protection Systems for Protection of special Risks, if any:		N/A	N/A	N/A
20						

Note:

The Management has been submitted a undertaking (see at 13) for demolished of old block ground & 02 upper floors and we requested to consider the Fire Safety Certificate only for single block ground & first floor.

The fire protection systems provided in the building were tested/ checked randomly and found in working condition, at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. 2951 dated 26.12.2014.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by Director of Education dated 01.03.2011, it is recommended to grant Fire Safety Certificate

DO/NW

[Signature]
27/12/2022
29/12/2022

[Signature]
27/12/2022

[Signature]
29/12/2022

[Signature]
29/12/2022

[Signature]
29/12/2022

[Signature]
Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

Conf. P.T.O.