



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**


No: F.6/DFS/MS/School/WZ/2023/ 10

Dated: 06/01/2023

**FIRE SAFETY CERTIFICATE**

Certified that the building of **Adarsh Shiv Shakti Shiksha Samiti (Regd.)** Located at **64, Chanderlok Enclave, Pitampura, New Delhi -110034** comprised of Basement + Ground + 03 upper floors was issued FSC vide letter No. F6/DFS/MS/SCHOOL/WZ/2019/568 dated 15/03/2019. The premises was re inspected by the officer concerned by this department on 29/12/2022 in the presence of Sh. Jatinder Duggal and observed that fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance DOE circular 3298-3398 dated 01/03/2011 and that the premises is fit for occupancy class "Educational" Group-B, with effect from 06/01/2023.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 Condition mentioned below.

Issued on 06/01/2023 at New Delhi.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy to: -

1. The Principal, Adarsh Shiv Shakti Shiksha Samiti (Regd.) Located at 64, Chanderlok Enclave, Pitampura, New Delhi -110034.
2. Director of Education, Old Secretariat, New Delhi-110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

### INSPECTION REPORT

1. Name & address of the building : Adarsh Shiv Shakti Shiksha Samiti (Regd.) Located at 64, Chanderlok Enclave, Pitampura, Delhi - 110034.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/WZ/2019/568 dated 15/03/2019
5. Fire Safety directives letter No : Circular No. 3298-3398 dated 01/03/2011
6. Date of inspection : 29/12/2022
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side : Mr. Jatinder Duggal
9. Year of Construction : 2008 (As per pre. insp. report dated 05/03/2019)
10. Applicant's letter No. : Letter no. PP/DFS/2022-23/02 dated 05/12/2022

**\* The said school is comprised of Basement + Ground + 03 Upper Floors + Tin Shed at Terrace.**

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Cr. No. 3298-3398 dtd.01-03-2011 As per pre. insp. report dated 05/03/2019 | Provided at site              | Remarks MR/NMR |
|--------|---|--|-------------------------------|----------------|
| 1      | <b>Access to building</b>                                   |  |                               |                |
|        | • Road width  | 6m   | Provided                      | MR             |
|        | • Gate width  | 4.5 m  | Provided                      | MR             |
|        | • Width of internal road                                    | NA   | NA                            | NA             |
| 2      | <b>Number, Width, Type &amp; Arrangement of Exits</b>       |  |                               |                |
|        | a. Number of staircases                                     |  |                               |                |
|        | • Upper Floors  | 01   | Provided                      | MR             |
|        | • Basements   | 02   | Provided                      | MR             |
|        | b. Width of staircases                                      |  |                               |                |
|        | • Upper Floors  | 1 x 150cm  | 1 x 135cm & 1 x 125cm         | MR (old case)  |
|        | • Basements   | 1 x 150cm  | 2 x 135cm                     | MR(old case)   |
|        | c. Protection of exits                                      |  |                               |                |
|        | • Fire check door   | NA   | NA                            | NA             |
|        | • Pressurization  | NA   | NA                            | NA             |
|        | e. No. of continuous staircases to terrace                  | 01   | Provided                      | MR             |
|        | f. Width of Corridor  | NA   | NA                            | NA             |
|        | g. Door Size  | 1 mts  | 100 cm (Including door frame) | MR             |
| 3      | <b>Compartmentation.</b>                                    |  |                               |                |
|        | • Fire check door   | NA   | NA                            | NA             |
|        | • Sealing of electrical shafts                              | NA   | NA                            | NA             |
|        | • Fire Rating of shaft door                                 | NA   | NA                            | NA             |
|        | • Water Curtain   | NA   | NA                            | NA             |
|        | • Fire Dampers  | NA   | NA                            | NA             |
| 4      | <b>Smoke Management System.</b>                             |  |                               |                |
|        | • Basements   | Required   | Provided (Exhaust Fan)        | MR             |
|        | • Upper floors  | NA   | NA                            | NA             |
| 5      | <b>Fire Extinguishers</b>                                   |  |                               |                |
|        | • Total numbers   | 12 nos.  | Provided                      | MR             |
|        | • Types   | CO <sub>2</sub> , ABC type   | Provided                      | MR             |
|        | • IS marking  | ISI marked   | Provided                      | MR             |

|    |  |             |              |    |
|----|--|-------------|--------------|----|
| 6  | <b>First-Aid Hose Reels.</b>   |             |              |    |
|    | <ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>      | 01          | Provided     | MR |
|    | <ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>         | 30 mtr      | Provided     | MR |
|    | <ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>                  | 5 mm        | Provided     | MR |
| 7  | <b>Automatic fire detection and alarming system.</b>                               |             |              |    |
|    | <ul style="list-style-type: none"> <li>Type of detectors</li> </ul>                | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>           | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>       | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>        | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>                | NA          | NA           | NA |
| 8  | <b>MOEFA</b>   | NA          | Provided     | NA |
| 9  | <b>Public Address System.</b>  | NA          | Provided     | NA |
| 10 | <b>Automatic Sprinkler System.</b>   |             |              |    |
|    | <ul style="list-style-type: none"> <li>Basement</li> </ul>                         | Required    | Provided     | MR |
|    | <ul style="list-style-type: none"> <li>Upper Floor</li> </ul>                      | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>    | NA          | NA           | NA |
| 11 | <b>Internal Hydrants</b>   |             |              |    |
|    | <ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>         | NA          | Provided     | NA |
|    | <ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>     | NA          | One Provided | NA |
|    | <ul style="list-style-type: none"> <li>Hose Box</li> </ul>                         | NA          | One Provided | NA |
| 12 | <b>Yard Hydrants.</b>  |             |              |    |
|    | <ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>         | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>Hose Box</li> </ul>                         | NA          | NA           | NA |
| 13 | <b>Pumping Arrangements.</b>   |             |              |    |
|    | <ul style="list-style-type: none"> <li>Ground Level</li> </ul>                     |             |              |    |
|    | <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>         | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>              | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>           | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>            | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>               | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>           | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>              | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>➤ Auto Starting/ Manual stopping</li> </ul> | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>              | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>Terrace level</li> </ul>                    |             |              |    |
|    | <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>              | 450 lpm x 2 | Provided     | MR |
|    | <ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>               | 40 m        | Provided     | MR |
|    | <ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>                   | Required    | Provided     | MR |
|    | <ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>          | Required    | Provided     | MR |
| 14 | <b>Captive Water Storage for fire fighting.</b>                                    |             |              |    |
|    | <ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>        | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>            | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>             | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>                 | NA          | NA           | NA |
|    | <ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>           | 15,000 Ltrs | Provided     | MR |
| 15 | <b>Exit Signage.</b>   | Required    | Provided     | MR |

Provision of Lifts.

|    |  |    |    |    |
|----|--|----|----|----|
| 16 | • Pressurization of Lift Shaft   | NA | NA | NA |
|    | • Pressurization of Lift lobby   | NA | NA | NA |
|    | • Communication In lift Car  | NA | NA | NA |
|    | • Fireman's Grounding Switch   | NA | NA | NA |
|    | • Lift Signage   | NA | NA | NA |
| 17 | Standby power supply   | NA | NA | NA |
| 18 | Refuge Area.   |    |    |    |
|    | > Total Area   | NA | NA | NA |
|    | > Location   | NA | NA | NA |
| 19 | Fire Control Room  |    |    |    |
|    | • Detector System Panel  | NA | NA | NA |
|    | • Flow Switch Panel  | NA | NA | NA |
|    | • PA System Panel  | NA | NA | NA |
|    | • Batter backup  | NA | NA | NA |
|    | • Building Floor Plans   | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/School/WZ/2022/487 dated 23/08/2022 have been complied.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no.F6/DFS/MS/SCHOOL/WZ/2019/568 dated 15/03/2019 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

413/ADO/MN  
29/12/22

AD (W)  
on leave

AD (W 2)  
27/1/2023

*[Signature]*  
29/12/22

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADO (MN)

~~AD (MN)~~

Sir, F.T is put up for your kind personal & signature please.

*[Signature]*  
03/01/2023

AD (W 2)  
5/1/2023

ms/ceff