



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No. F6/DFS/MS/EH/NDZ/2023/ 06

Dated: 06 / 01 / 2023

FIRE SAFETY CERTIFICATE

Certified that the M/s **Darbar Chicken & Fish Fry** located at **A31/152A, Gr.Floor, Road No.66, Maujpur, Delhi - 110053**, building comprised of Ground + One upper Floor but Restaurant is running on Ground Floor only, owned / occupied by M/s Darbar Chiken & Fish Fry, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2019/NDZ/1913 dated 07/10/2019. The premises was re-inspected by the officers concerned of this department on 30/12/2022 in the presence of Sh. Nadeem (Manager) and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class **"Assembly" Group-D (Restaurant)** with effect from 06 / 01 / 2023 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on 06/01/23 at New Delhi by.


(S.K.DUA)

**Dy. CHIEF FIRE OFFICER
DELHI FIRE SERVICE.**

Copy to:-

1. Darbar Chiken & Fish Fry, A31/152A, Gr.Floor, Road No.66, Maujpur, Delhi - 110053.
2. The Deputy Commissioner (Licensing), 1st Floor, Police Station Defence Colony, New Delhi-110024 w.r.t. **Online Application ID no. 2022111019985 Dated 14/11/2022.**

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [subrule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: M/s Darbar Chiken & Fish Fry, A31/152A, Gr. Floor,
Road No.66, Maujpur, Delhi - 110053.
2. Building is comprised of : Ground plus One upper Floors (Restaurant is running
on Ground Floor only).
3. Type of Occupancy : Assembly (Restaurant)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/EH/2019/NDZ/1913 Dated 07/10/2019
6. Fire Safety directives Letter No.: NBC Part IV
7. Date of inspection : 30/12/2022
8. Name of the Inspecting Officer : D.O. (E.D.)
9. Name and designation of Officer
from the building side : Sh. Nadeem (Manager)
10. Year of Construction : 1994
11. Applicant's Online ID No. : 2022111019985 Dated 14/1/2022

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	09 m	24 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door size	2.0 m & 1.5 m	2.40m, 2.0 m x 2 & 0.70m	MR
3	Compartmentation			
	• Fire check Door	N/A	N/A	N/A
	• Sealing of electrical Shafts	N/A	N/A	N/A
	• Fire rating of Shaft Door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
5	Fire Extinguishers			
	• Total Numbers	04 Nos.	06 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS Marking	ISI Marked	ISI Marked	MR

AKS

N/A

6	First-aid-Hose Reels			
	Total numbers of each floor	01 Nos.	01 Nos.	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	Smoke	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's Location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false Ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of rise/down-comer	100 mm	100 mm	MR
	• Number of Hydrants per Floor	01 nos.	01 nos.	MR
	• Hose Box	01 nos.	01 nos.	MR
12	Yard Hydrants			
	• Total number of Hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main Pumps	N/A	N/A	N/A
	➤ Jockey pump output	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump output	N/A	N/A	N/A
	➤ Standby pump head	N/A	N/A	N/A
	➤ Auto starting/Manual stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• overhead Tank capacity	20,000 Ltrs.	Provided	MR
15	Exit Signage	Required	Provided	MR

N/A

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view, of the deemed compliance of the minimum standards of Fire Prevention and Fire Safety measures as required under the rules the NOC issue vide letter No. F6/DFS/MS/EH/2019/NDZ/1913 Dated 07/10/2019 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ashok
02/01/2023

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East. Div.).

Dy. CFO/(NDZ)

what is the use of 1st floor?

D.O.(NDZ)

1st floor
03/01/23
Is Floor is used as workers residence.

Dy. CFO/(NDZ)

Ashok
03/01/2023

F.T. please

D.O.(NDZ)

Sir,

F.T. is added for sign. pl.

Dy. CFO/(NDZ)

F.P. wing

1st floor
05/01/23

Ashok
04/01/2023

Ashok
9/1/23