

C-46

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/SCHOOL/SZ/2023/ 19

Dated: 06/01/2023

**FIRE SAFETY CERTIFICATE**

Certified that the building of Paramount International School Located at Sector 23, Dwarka, New Delhi – 110075 comprised of Ground + 03 Upper Floors (4<sup>th</sup> floor under construction & not in use) was issued FSC vide letter No. F6/DFS/MS/School/2018/SZ/305, dated 26/12/2018. The premises was re - inspected by the officer concerned of this department on 30/12/2022 in the presence of Ms. Rashmi Bajpai (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service 2010 and that the premises is fit for occupancy class "Educational" Group B( **Ground + 03 Upper Floors only** ) with effect from 06/01/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/01/2023 at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal Paramount International School Located at Sector 23, Dwarka, New Delhi – 110075.

**Following fire safety directives must be adhered to:-**

1. **The 4<sup>th</sup> floor shall not be use for any purpose without getting FSC from this department.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

**INSPECTION REPORT**

N-20

1. Name & address of the building: Paramount International School Located at Sector 23, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Educational ( Ground+3 Upper Floors (**4<sup>th</sup> floor under construction & not in use**))
3. Type of Case : Renewal
4. Details of previous NOC: F6/DFS/MS/School/2018/SZ/305 Dated 26/12/2018
5. Fire Safety directives L. No: F6/DFS/MS/BP/2004/2202, dated 24/09/2004 & F6/DFS/MS/BP/2018/School/32 Dated 31/10/2018
6. Date of inspection : 30-12-2022
7. Name of the Inspecting Officer :Udai Vir Singh, ADO (DWK)
8. Name and designation of Officer  
from the building side : Ms. Rashmi Bajpai (Principal)
9. Year of Construction : 2007
10. Applicant's letter No. : Email Dated 20/12/2022

Total Area = 8116 sqm.  
Covered Area = 1619 sqm  
Class rooms = 103  
No. of students = 2415

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/10, N/11 & N/12	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR (being old case)
	• Gate width	5 mtr	Provided	MR (being old case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	05 Nos.	05 Nos.	MR
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5 mtr each	3X1.5m, 1.31m & 1.33m	MR (being old case)
	• Upper floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	05 Nos.	05 Nos.	MR
	d. No of continuous staircase to terrace	1.5m	2.05 mtr	MR (being old case)
	e. Width Of Corridor			
	f. Door Size	01 mtr	Provided	MR

13

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA	NA	NA
		12 a/c charge	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	25 nos. ABC & CO <sub>2</sub> ISI marked	Provided	MR
			ABC & CO <sub>2</sub>	MR
			ISI marked	MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	02	Provided	MR
		30	Provided	MR
		05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>• Size of riser/down- comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	100 mm	Provided	MR
		02 Nos.	Provided	MR
		Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto starting/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 lpm & 180 lpm	Provided	MR
		30 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR




N-22

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	50,000 ltrs	Provided	MR
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter F6/DFS/MS/School/2018/SZ/305, dated 26/12/2018 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

  
 Signature of the Inspecting Officer  
 Name Udai Vir Singh  
 Designation ADO/DWK

