



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/EH/NDZ/2023/ 01

Dated: 06/01/2023

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Tarang Banquets Tarang Gardens and Banquets P. Ltd. hall located at Road No.56, Ghazipur, Delhi - 110096, running on Ground Floor only in building comprising Basement, Ground + Two upper Floors, owned/occupied by M/s Tarang Banquets Tarand Gardens & Banquets Pvt. Ltd., was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/BNQT/2019/NDZ/2305 Dated 12/12/2019. The Second Floor of the building has already been issued FSC for guest house purposes of 17 Guest Rooms by this department vide Letter No. F6/DFS/MS/2020/GH/NDZ/134 Dated 10/09/2020. The premises was re-inspected by the officer concerned of this department on 30/12/2022 in the presence of Sh. Vijay Malik (Director) and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class "Assembly" Group-D (Banquet Hall) with effect from 06/01/2023 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

**Issued on** 06/01/23 **at New Delhi by.**

  
(S.K.DUA)

**Dy. CHIEF FIRE OFFICER  
DELHI FIRE SERVICE.**

Copy to:-

1. Tarang Banquets hall located at Road No.56, Ghazipur, Delhi - 110096.
2. The Deputy Commissioner (Licensing), 1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi-110024 w.r.t. **Online Application ID no. 2022082316497 Dated 22/12/2022.**

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [subrule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**INSPECTION REPORT**

1. Name & address of the building: M/s Tarang Banquets, Tarand Gardens & banquets Pvt. Ltd.  
Road No.56, Ghazipur, Delhi - 110096.
2. Building is comprised of : Basement, Ground plus Two upper Floors  
**(Banquet is running at Ground Floor only)**
3. Type of Occupancy : Assembly (Banquet)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/BNQT/2019/NDZ/2305 Dated 12/12/2019
6. Fire Safety directives Letter No.: F6/DFS/MS/BP/2013/2135 Dated 02/09/2019
7. Date of inspection : 30/12/2022
8. Name of the Inspecting Officer : D.O. (E.D.)
9. Name and designation of Officer  
from the building side : Sh. Vijay Malik (Director)
10. Year of Construction : 2008
11. Applicant's Online ID No. : 2022082316497 Dated 22/12/2022

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV/UBBL Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	12 m	40 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door size	2.0 m	2.0 m x 3	MR
3	Compartmentation			
	• Fire check Door	Required	Provided	MR
	• Sealing of electrical Shafts	Required	Provided	MR
	• Fire rating of Shaft Door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	• Basement	30 ACPH	Exhaust Fan	MR
	• Upper Floor	12 ACPH	Natural	MR
5	Fire Extinguishers			
	• Total Numbers	10 Nos.	10 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS Marking	ISI Marked	ISI Marked	MR

N/33

	First aid Hose Reels		01 Nos.	MR
	Total numbers of each floor	01 Nos.	30 M	MR
	• Length of hose reel hose	30 M	05 mm	MR
	• Nozzle diameter	05 mm		
7	Automatic fire detection and alarming system		Provided	MR
	• Type of detectors	Heat/Smoke	Provided	MR
	• Location of main panel	Required	Provided	MR
	• Location of repeater panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's Location	Required	Provided	MR
8	MOEFA	Required	Provided	N/A
9	Public address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false Ceiling	N/A	N/A	N/A
	Internal Hydrants			
	• Size of rise/down-comer	100 mm	100 mm	MR
	• Number of Hydrants per Floor	01 nos.	01 nos.	MR
	• Hose Box	01 nos.	01 nos.	MR
	Yard Hydrants			
	• Total number of Hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main Pumps	N/A	N/A	N/A
	➤ Jockey pump output	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump output	N/A	N/A	N/A
	➤ Standby pump head	N/A	N/A	N/A
	➤ Auto starting/Manual stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	1620 LPM	1620 & 450 LPM	MR
	➤ head of the pump	40 MH	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
	Captive Water Storage for Fire Fighting			
	Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	overhead Tank capacity	20,000 Ltrs.	Provided	N/A
	signage	Required	Provided	MR

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	Required	HT & LT panel protected with local application i.e. CO2 fire extinguishers	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view, of the deemed compliance of the minimum standards of Fire Prevention and Fire Safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/BNQT/2019/NDZ/2305 Dated 12/12/2019 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*Approved*  
02/01/2023

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : D.O. (East. Div.).

~~Dy. CFO (NDZ)~~

F.T. please.

*King*  
03/01/23

~~DO (ED)~~ Sis,  
As Approved, F.T. is added for sign. A.

~~Dy. CFO (NDZ)~~

*Approved*  
04/01/2023

*King*  
06/01

F.P. wing

*Approved*  
9/1/23