

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F.6/DFS/MS/School/2023/SZ/ 25

Dated: 11/01/2023

FIRE SAFETY CERTIFICATE

Certified that the Surya Model School, T-Extension, Uttam Nagar, New Delhi-110059, comprised of ground plus four upper floors, owned/occupied by Surya Model School have complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 02/01/2023 in the presence of Sh. Rajesh Gupta (Chairman) of the school and that the school building is fit for occupancy class B 'Educational Building' for with effect from 11.01.2023 for a period of **three** years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....11/01/2023.....at New Delhi by


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Principal, Surya Model School, T-Extension, Uttam Nagar, New Delhi-110059.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
3. Executive Engineer Building, MCD Civic Centre to measure the height of the building

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Basement shall be used as per BBL.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

11/7

- 1. Name & address of the building : Surya Model School, T-Extension, Uttam Nagar, New Delhi-110059.
- 2. Building is comprised of : ground plus four upper floors.
- 3. Type of Occupancy : Educational
- 4. Type of Case : New Case
- 5. Details of Previous FSC letter : Nil
- 6. Fire Safety direction letter No : N/A
- 7. Date of Inspection : 02/01/2023
- 8. Name of the Inspecting officers : ADO R.K. Yadav
- 9. Name and designation of Officer: : Sh. Rajesh Gupta (Chairman)
- 10. Year of Construction : Before 2006 & 2016
- 11. Applicant's letter No : SMS/01/2022-23 Dated- 15/11/2022

S. N	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building	06 m.	Provided	MR
	• Road width	N/A	N/A	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road			
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 Nos.	2 Nos.	MR
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	B. Width of Staircases	1.5 m Each	1.5 m Each	MR
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	Two	Provided	MR
	d. No. of continuous staircases to terrace	1.5 M	Provided	MR
	e. Width of Corridor	1.0 m	1.0 m	MR
	f. Door Size			
3	Compartmentation.	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.	N/A	N/A	N/A
	• Basement	Required	Natural Ventilation	MR
	• Upper floor			
5.	Fire Extinguishers	15 nos.	Provided	MR
	• Total numbers	ABC /CO ₂	ABC /CO ₂	MR
	• Types	IS I marked	ISI marked	MR
	• IS marking			

17

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 No	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 No.	Provided	MR
	• Hose Box	01 No.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR



16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures under Rule 35 of the Delhi Fire Service Rules 2010 it is recommended to grant Fire Safety Certificate.

Note :-As per the structure stability certificate placed at C-20 total height of the said building does not exceed height 14.65 Mtr. Approx.

R.K. Yadav
3/11/2023

Signature of the Inspecting Officer
Name- R.K. Yadav
Designation- A.D.O (JKP)

DO (South West)
AD
4/1/23

Dyefo (S2)

F.T.
[Signature]
4/1/23

CFO. Vnegh
4/1/2023
Director
3/11/23

FT Plc
[Signature]
3/11/23

Asst JKP