



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/Indl./2023/NDZ/ 22

Dated: 13/01/2023

FIRE SAFETY CERTIFICATE

Certified that the Plot No. 346, FIE Patparganj Industrial Area, Delhi-92, building comprised of **Basement, Ground plus One Upper Floor**, owned/occupied by Sage Metals Ltd., have already been issued NOC/FSC vide letter No. F6/DFS/MS/Indl./2019/NDZ/2137Dt. 14/1/2019. The premises was re-inspected by the officers concerned of this department on 07/01/2023 in presence of Sh. Parvez Ansari and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises, found in good working condition. The Premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Industrial**" (Group G-1) with effect from 13/01/2023 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 13/01/2023 at New Delhi by


13/01/23
(S.K.DUA)

DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Manager, Plot No. 346, FIE Patparganj Industrial Area, Delhi-92.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building: Plot No. 346, FIE Patparganj Industrial Area, Delhi-92.
2. Building is comprised of : Basement, Ground + 1 Upper Floor
3. Type of Occupancy : Industrial (Low Hazard) G-1
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/Indl./2019/NDZ/2137Dt. 14/1/2019 ✓
6. Fire Safety directives Letter No.: Nil
7. Date of inspection : 07/01/2023
8. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (E.D.) & Deepak Kumar ADO (Shahd)
9. Name and designation of Officer
from the building side : Sh. Parvez Ansari
10. Year of Construction : 1997-98
11. Applicant's Letter No. : Nil Dated 02/11/2022 Outdoor Dairy No. 21/11/2022

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/ NBC Part-IV	Provided at Site	Remarks
1	Access to building			
	• Road width	12 m	12 m	M/R
	• Gate width	4.5 m	4.5 m	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 nos.	02 nos.	MR ✓
	• Basement	02 nos.	02 nos.	MR
	b. Width of Staircases			
	• Upper Floor	1.40 & 0.90 m	1.40 & 0.90 m	MR
	• Basement	1.40 & 1.25 m	1.40 & 1.30 m	MR ✓
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 nos.	01 nos.	MR
	e. Width of Corridor	1.5 m	1.5 m	MR
	f. Door size	N/A	N/A	N/A
3	Compartmentation			
	• Fire check Door	Required	Provided	MR
	• Sealing of electrical Shafts	N/A	N/A	N/A
	• Fire rating of Shaft Door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	• Basement	Required	Provided	MR ✓
	• Upper Floors	N/A	N/A	N/A
5	Fire Extinguishers			
	• Total Numbers	10 Nos.	Provided	MR ✓
	• Types	ABC & Co2	ABC & Co2	MR
	• IS Marking	ISI Marked	ISI Marked	MR

E. 

N/7

6	First-aid-Hose Reels			
	• Total numbers of each floor	01 Nos.	01 Nos.	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false Ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of rise/down-comer	100 MM	100 MM	MR
	• Number of Hydrants per Floor	01 No.	01 No.	MR
	• Hose Box	01 No.	01 No.	MR
12	Yard Hydrants			
	• Total number of Hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main Pumps	N/A	N/A	N/A
	➤ Jockey pump output	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump output	N/A	N/A	N/A
	➤ Standby pump head	N/A	N/A	N/A
	➤ Auto starting/Manual stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ head of the pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage	15,000 Ltrs.	15,000 Ltrs.	MR

2.

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/Indl./2019/NDZ/2137Dt. 14/1/2019, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Approved
10/01/2023

Deepak
10/01/2023

Signature of the Inspecting Officer
Name: Ashok Kumar Jaiswal
Designation: D.O. (East. Div.)

Signature of the Inspecting Officer
Name: Deepak Kumar Hooda
Designation: ADO (Shahdara)

~~DCFO (NDZ)~~ . F.T. please.

~~DO (ED)~~ *Kiry*
11/01/23

~~[scribble]~~ F.T. is added for sign. pl.

~~Dy. CFO (NDZ)~~

F.P. wing

Kiry
12/01/23

AM
13/01/2023