



C-59

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2023/11

Dated: 11/01/2023

FIRE SAFETY CERTIFICATE

Certified that the **M/s Shyama Inn** situated at **5050/12, Netaji Subash Marg, Daryaganj, Delhi - 06**, comprised of **ground floor-** (commercial use), **1st floor** - (06 guest rooms + reception), **2nd floor** - (04 guest rooms + owners residence) & **3rd floor** - (mumty + 02 store rooms + water tank + tin shed for domestic use). **total 10 guest rooms** was granted **FSC** by this department vide letter no. F6/DFS/MS/GH/NDZ/2019/2283 dated 10.12.2019. Now, the building/ premises was re-inspected by the officer concerned of this department on dated 30.12.2022 in presence of Mr. Rohit Sukhija (Owner) and found that the building is comprised of **ground + mezzanine + 03 upper floors** and now the floor wise occupancy is **ground floor-** (commercial use), **mezzanine** - (commercial use), **1st floor** (06 guest rooms + reception), **2nd floor-** (04 guest rooms + owner residence) & **3rd floor-** (not in use as per affidavit dated 31.12.2022). The building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of "**Residential (Sub Division-A-1), 1st floor** (06 guest rooms), **2nd floor** - (04 guest rooms), **total 10 guest rooms upto 2nd floor only**, with effect from 11/01/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 11/01/2023 at New Delhi by


11/01/23
(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service
Tel: 011-23412222

Copy to:-

1. The Commissioner, MCD:- to kindly ensure the occupancy as detailed above & deviation, if any.
2. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2022122221677 dated 22.12.2022.
3. The Licensee, M/s Shyama Inn at 5050/12, Netaji Subash Marg, Daryaganj, Delhi - 06.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' (sub Rule (I) of Rule 37) along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.
8. The occupancy of any floor above 2nd floor not allowed as per clause 7.31 in UBBI-2016.

INSPECTION REPORT

1	Name & address of the building	M/S Shyama Inn, 5050/12, Netaji Subash Marg, Daryaganj, Delhi - 06.		
2	Building is comprised of	(Ground + Mezzanine + 03 upper floors) Ground floor (Commercial use) Mezzanine (Commercial use) 1 st floor (06 guest rooms + reception) 2 nd floor (04 guest rooms + Owner residence) 3 rd floor (not in use as per affidavit dated 31.12.2022)		
3	Type of occupancy	Residential, Sub Division A 1		
4	Type of case	Renewal (old case)		
5	Details of previous FSC	F6/DIFS/MS/GH/N/DZ/2019/2283 dated 10.12.2019		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	30.12.2022		
8	Name of the inspecting officers	DO (CD) & ADO (SPM)		
9	Name of the designation of officer from the building side	Mr. Rohit Sukhija (Owner)		
10	Year of construction	2010		
11	Applicant's letter no.	Online application I.D. No. 2022122221677 dated on 22.12.2022		
S.N	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/ NMR
1	Access To Building:			
	Road width	Accessibility	30 mtr.	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	01 nos.	02 nos. from ground to 1 st , 01 nos. from 1 st to upper floors	MR
	b Basement	NA	NA	NA
	B Width of staircases			
	a Upper floor	0.80 mtr.	0.85 mtrs., 1.17 mtrs. to 1.25 mtrs.	MR
	b Basement	NA	NA	NA
	C Protection of exits			
	a Fire check door	NA	NA	NA
	b Pressurization	NA	NA	NA
	D No. of continuous staircases to terrace	01 nos.	01 nos.	MR
	E Width of corridor	NA	NA	NA
	F Door size	1.0 mtrs.	1.0 mtrs.	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft door	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke Management System:			
	A Basement	NA	NA	NA
	B Upper floor	12 ACPH	Natural/Ventilated	MR

5. Fire Extinguisher:				
A	Total numbers	07 nos.	07 nos.	MR
B	Types	ABC & Co2	ABC & Co2	MR
C	ISI marking	Required	Provided	MR
6 First-Aid-Hose Reels:				
A	Total numbers of each floor	1 nos.	01 nos.	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection And Alarming System:				
A	Type of detectors (CO type)	Required	Provided	MR
B	Location of main panel	Required	Provided at 1 st floor	MR
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	Required	Provided	MR
E	Hooters	Required	Provided	MR
8 MOEFA:				
		NA	Provided	NA
9 Public Address System:				
		NA	Provided	NA
10 Automatic Sprinkler System:				
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
11 Internal Hydrants:				
A	size of riser/down-comer	NA	NA	NA
B	Number of hydrants per floor	NA	NA	NA
C	Hose box	NA	NA	NA
12 Yard Hydrants:				
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13 Pumping Arrangements:				
A Ground level				
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pumps	NA	NA	NA
d)	Jockey pump out put	NA	NA	NA
e)	Jockey pump head	NA	NA	NA
f)	Standby pump out put	NA	NA	NA
g)	Standby pump head	NA	NA	NA
h)	Auto starting /manual stopping	NA	NA	NA
B Terrace level				
a)	Discharge of pump	225 LPM	225 LPM	MR
b)	Head of the pump	40 mtrs.	40 mtrs.	MR
c)	Power supply	Required	Provided	MR
d)	Auto starting of pump	Required	Provided	MR


68 62


14	Captive Water Storage For Fire Fighting:			
	A Underground tank capacity	NA	NA	NA
	B Draw off connection	NA	NA	NA
	C Fire service inlet	NA	NA	NA
	D Access to tank	Required	Provided	MR
	E Overhead tank capacity	2,500 ltrs.	5,000 ltrs.	MR
15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts:			
	A Pressurization of lift shaft	NA	NA	NA
	B Pressurization of lift lobby	NA	NA	NA
	C Communication in lift car	NA	NA	NA
	D Firemen's grounding switch	NA	NA	NA
	E Lift signage	NA	NA	NA
17	Standby Power Supply:	Required	Provided	MR
18	Refuge Area:			
	A Total area	NA	NA	NA
	B Location	NA	NA	NA
19	Fire Control Room :			
	A Detector system panel	NA	NA	NA
	B Flow switch panel	NA	NA	NA
	C Pa system panel	NA	NA	NA
	D Battery backup	NA	NA	NA
	E Building floor plans	NA	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:			

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Shortcomings communicated vide letter No.F6/DFS/MS/GH/NDZ/2022/405 dated 30/05/2022 have been rectified.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2019/2283 dated 10.12.2019 is recommended to be renewed upto 2nd floor only, under Rule 35 of the Delhi Fire Service Rules 2010.


 5/1/23
 Signature of the Inspecting Officer
 Name Rajinder Atwal
 Designation DO (CD)


 05/01/2023
 Signature of the Inspecting Officer
 Name Sumit Kumar
 Designation ADO (SPM)

~~Dy. C.F.O.~~

F.T. please.



 06/01

ADO (SPM)

F.T. letter is Put up for Signature, Please.

~~Dy. C.F.O. (NDZ)~~
 F.P. wing


 11/01/23


 10/01/2023
 Uploaded
 13/1/23
