

C-32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2023/SZ/ 31

Dated: 16/01/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Co-Ed. Sr. Sec. School, Hasanpur, New Delhi-110073, comprised of ground floor only, having total 10 rooms (Including class rooms, Science Lab, Computer Lab, Staff Room, Math Lab & office etc.) owned/occupied by Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2020/SZ/78 dated 26/02/2020. The school building was re- inspected by the officer concerned of this department on 22/12/2022 in the presence of Sh. B.L Meena (Principal) and found that the Govt. Co-Ed. Sr. Sec. School have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....16/01/2023..... at New Delhi.



(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER  
SOUTH ZONE

**Copy to:-**

1. The Principal, Govt. Co-Ed. Sr. Sec. School, Hasanpur, New Delhi-110073.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

**INSPECTION REPORT**

- Name & address of the building : Govt. Co-Ed. Sr. Sec. School, Hasanpur, New Delhi-110073  
 Building comprised of : Ground floor only  
 Type of Occupancy : Educational  
 Type of Case : Renewal  
 Details of Previous NOC : F.6/DFS/MS/School/2020/SZ/78 dated 26/02/2020  
 Fire Safety directives letter No : Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011  
 Date of inspection : 22/12/2022  
 Name of Inspecting Officer : A.D.O. R.K.Yadav  
 Name and designation of officers : Sh. B.L Meena (Principal)  
 From the building side :  
 Year of Construction : 1995  
 Applicant's letter No. : HNP/2022/574 dated 07/12/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Circular Dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	06 M N/A N/A	Provided N/A N/A	M/R N/A N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	N/A N/A	N/A N/A	Ground floor only N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	N/A N/A	N/A N/A	Ground floor only N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	Old Case	.97 m (Double door)	M/R, being old case
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	N/A N/A	N/A N/A	N/A N/A
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	04 no's ABC/CO <sub>2</sub> type  ISI marked	15 no's Provided Provided ISI marked	M/R M/R M/R



N/18

Provision of Lifts.

(No Lift)

N/A	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
N/A		N/A	N/A	N/A
N/A		N/A	N/A	N/A
N		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2020/SZ/78 dated 26/02/2020 renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.



Signature of Inspecting Officer  
 Name:- R.K.Yadav  
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

Dy CEO (SZ)

A O O / PNB

3/11/23

