

E 140

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2023/BHQT/02

Dated: 06/01/2023

**FIRE SAFETY CERTIFICATE**

Certified that the building of M/s Surya Garnd Banquet (A unit of RJS Banquets LLP) Located at WZ-306, S-1, Khasra No-72/14/2/& 15, Chaudhty Data ram Marg, Palam Extension, Behind Shri Niketan CGHS Ltd, New Delhi, in a building comprised of Basement + Stilt + Ground + Two Upper Floors was issued FSC vide letter No. F6/DFS/MS/2020/SZ/BHQT/91, dated-03/02/2020, owned/ occupied by **M/s Surya Grand Banquet**. The premises was re - inspected by the officer concerned of this department on 30/12/2022 in the presence of Sh. Joginder Singh and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class " Assembly" Group D (**Banquet Hall**) with effect from 06/01/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/01/2023 at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:

1. The Addl. Commissioner of Police, Licensing Unit 1st Floor, P.S Defence Colony, New Delhi- 110049.
2. Deputy Health Officer, Health Department, SDMC, Dhansa stand, Najafgarh, New Delhi - 110043.
3. Sh. Joginder Singh (Director), M/s Surya Garnd Banquet Located at WZ-306, S-1, Khasra No-72/14/2/& 15, Chaudhty Data ram Marg, Palam Extension, Behind Shri Niketan CGHS, New Delhi.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/26  
**INSPECTION REPORT**

1. Name & address of the building: M/s Surya Garnd Banquet (A unit of RJS Banquets LLP) Located at WZ-306, S-1, Khasra No-72/14/2/& 15, Chaudhty Data ram Marg, Palam Extension, Behind Shri Niketan CGHS Ltd, New Delhi.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2020/SZ/BHQT/91, dated-03/02/20
5. Fire Safety directives L. No : F-6/DFS/MS/BP/2019/4912 dated-14/08/2019
6. Date of inspection : 30/12/2022
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. Joginder Singh
9. Year of Construction : 2012
10. Applicant's letter No. : 2022111420134, dated 15/11/2022

Basement= Parking & Storage  
Stilt= Office  
Ground = Hall  
1<sup>st</sup> floor= Hall  
2<sup>nd</sup> floor= Hall

S No	Minimum standards on fire prevention and fire safety U/R 33	AS Per N/17, N/18 & N19	Provided at site	Remarks MR/NMR
1.	<b>Access of building</b>			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	Required as per plan	Provided	MR
2.	<b>Number, width, Type &amp; Arrangements of exits</b>			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	2m,1.5m	Provided	MR (Old Case)
	• Basements	1.40mtrs. each	Provided	MR (Old Case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m,1.5m	Provided	MR (Being old Case)
3.	<b>Compartmentation</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	2 Hrs	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA



CO2 Fire Extinguisher

N/26  
MP

N/27

4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 AC Change	Provided	MR
		12 AC Change	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	04 nos. at each floor ABC & CO2 ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Required Ground Floor N/A Battery Backup Appropriate Location	Provided Ground Floor N/A Battery & DG Provided	MR MR N/A MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required NA NA	Provided NA NA	MR NA NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm 02 Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	01 Provided Provided	NA NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	2280 lpm 50m 1 180lpm 50m 2280lpm 50m Required Required 900 lpm 40 m Required Required	Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided	MR MR MR MR MR MR MR MR MR MR MR MR MR

14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	100000 Ltrs	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area	NA	NA	
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Co2 Fire Extinguisher Provided Near HT/LT Panels	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter F6/DFS/MS/2020/SZ/BHQT/91, dated-03/02/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*[Signature]*  
 Signature of the Inspecting Officer  
 Name UdaiVir Singh  
 Designation ADO/ DWK

*[Signature]*  
 Numbers of floors are not matching with previous inspection report and FSG noting at N-8. Recheck the same

*[Signature]*  
 ADO (Dwarka)

*[Signature]*  
 2/1/22  
 D.O(SW)