

e-24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2023/32

Dated: 16/01/2023

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Secondary School, Deputy Ganj, Delhi- 06**, comprised of Ground + 01 upper floors, having total (06 class rooms + 01 store + 01 library + 01 office + 02 labs) was granted Fire Safety Certificate by this department vide letter no.F6/DFS/MS/School/NDZ/2020/06 dated 09.01.2020. The building/ premises was re-inspected by the officer concerned of this department on 05.01.2023 in the presence of Mrs. Sushila Bundela (HOS) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011 issued by the Director of Education and found that the building having **GF + FF** is fit for occupancy of class (**Group-B**) "**Educational Building**" with effect from ... 16/01/2023... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on ... 16/01/2023 at New Delhi by

(Signature)
11/01/23

(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Tel: 011-23412222

o/c

16/01

Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal,
Govt. Girls Secondary School, Deputy Ganj, Delhi- 06.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in ease of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in schedule of Delhi Fire Service Rule 2010.

INSPECTION REPORT

- 1 Name and address of the building: Govt. Girls Secondary School at Deputy Ganj, Sadar Bazar, Delhi - 06.
- 2 Type of occupancy with details of floors: Educational Building Group -B-1 (Ground + 01 upper floor)
- 3 Type of case: Renewal case (old case)
- 4 Details of previous FSC: F6/DFS/MS/School/NDZ/2020/06 dated 09.01.2020
- 5 Fire safety directives no.: NA
- 6 Date of inspection: 05.01.2023
- 7 Name of the inspecting officer: Sh. Sumit Kumar, ADO (SPM)
- 8 Name and designation of the officer from the building side: Mrs. Sushila Bundela (HOS)
- 9 Year of construction: 2009
- 10 Reference letter no.: Outdoor diary no. 9523 dated 28.12.2022

S. No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	As per Education Circular	Provide at site	Remarks MR/NM/R
1	Access to Building			
A	Road width	06 mtr.	06 mtr.	MR
B	Gate width	4.5 mtrs.	05 mtrs.	MR
C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
A	No. of Staircase:			
	a) Upper floor	01 nos.	01 nos.	MR
	b) Basements	NA	NA	NA
B	Width of the Staircase:			
	a) Upper floor	1.5 mtrs.	1.52 mtr.	MR
	b) Basements	NA	NA	NA
C	Protection of Exits			
	a) Fire check door	NA	NA	NA
	b) Pressurization	NA	NA	NA
D	No. of continuous staircase to terrace:	NA	NA	NA
F	Width of the corridor	NA	NA	NA
E	Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
A	Fire check doors	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft doors	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	Smoke management System:			
A	Basements	NA	NA	NA
B	Upper floors	NA	NA	NA
5	Fire extinguishers			
A	Total numbers	07 nos.	07 nos.	MR
B	Types	ABC & Co2	ABC & Co2	MR
C	ISI marking	Required	Provided	MR

8

8

6	First Aid Hose reel	NA	NA	NA
A	Total no. at each floor	NA	NA	NA
B	Length of Hose Reel	NA	NA	NA
C	Nozzle diameter	NA	NA	NA
7	Automatic Fire Detection and Alarm System (ADAS)	NA	NA	NA
A	Type of Detectors	NA	NA	NA
B	Location of main Panel	NA	NA	NA
C	Location of Repeater Panel	NA	NA	NA
D	Alternate power Source	NA	NA	NA
E	Hooter's location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System	NA	NA	NA
A	Basement	NA	NA	NA
B	Upper Floor	NA	NA	NA
C	Sprinklers above false ceiling	NA	NA	NA
11	Internal hydrants	NA	NA	NA
A	Size of the riser/down comer	NA	NA	NA
B	No. Of hydrants per floor	NA	NA	NA
C	Hose box	NA	NA	NA
12	Yard Hydrants	NA	NA	NA
A	Total no. of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13	Pumping arrangements	NA	NA	NA
A	Ground Level	NA	NA	NA
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pump	NA	NA	NA
d)	Discharge of jockey pump	NA	NA	NA
e)	Head of jockey pump	NA	NA	NA
f)	Discharge of Standby pump	NA	NA	NA
g)	Head of Standby pump	NA	NA	NA
h)	Auto starting/ manual stopping	NA	NA	NA
B	Terrace Level	NA	NA	NA
a)	Discharge of terrace pump	NA	NA	NA
b)	Head of terrace pump	NA	NA	NA
c)	Alternate power supply	NA	NA	NA
d)	Auto starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting	NA	NA	NA
A	Underground tank capacity	NA	NA	NA
B	Draw off connection	NA	NA	NA
C	Fire Service Inlet	NA	NA	NA
E	Access to tank	NA	NA	NA
D	Overhead tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16	Provision of lift	NA	NA	NA
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Fireman switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	Standby Power Supply	NA	NA	NA

18	Refuge Area	NA	NA	NA
	A location	NA	NA	NA
	B Total area	NA	NA	NA
19	Fire Control Room	NA	NA	NA
	A Fire Detection System panel	NA	NA	NA
	B Flow switch panel	NA	NA	NA
	C P A system panel	NA	NA	NA
	D Battery backup	NA	NA	NA
	E Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any:			

The fire protection systems provided in the school were tested, checked at random found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required as per Director Education, Circular FSC issued vide letter in. F6/DPS/MS/School/NDZ/2020/06 dated 09.01.2020, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer
 Name Sumit Kumar
 Designation ADO (SPM)

Sumit Kumar
 05/01/2023

DO (ED)

[Signature]
 6/1/23

[Signature]
 D.P. wing

ADO (SPM)

F.T. please

[Signature]
 09/01/23

F.T. letter is Put up for Signature, Please.

Dy. C.O. (NDZ)

[Signature]
 F.P. wing

Sumit Kumar
 10/01/2023

[Signature]
 11/01/23