

c/66

7. DPA  
7. अग्नि सुरक्षा विभाग  
आग्नि सुरक्षा विभाग

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**


No. F.6/DFS/MS/GH/WZ/2022/ 26

Dated: 19/01/2023

**FIRE SAFETY CERTIFICATE**

Certified that the M/s. **Bikanerwala Foods Pvt. Ltd**, located at **A-28, Lawrence Road, Industrial Area, New Delhi-110035** comprised of Basement + Ground + 01 upper floor Owned/Occupied by M/s. **Bikanerwala Foods Pvt. Ltd**, was issued FSC vide letter no. F6/DFS/MS/WZ/2020/60 dated 23/01/2020 the premises was re-inspected by the officer concerned of this department on 27/12/2022 in the presence of Sh. Pushpender and found that the said building have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire service Rules, 2010 and that the said building is fit for occupancy class "Industry" Group - G with effect from 19/01/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 conditions printed overleaf.

Issued on 19/01/2023 at New Delhi by.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy to: -

1. The owner/ Occupier, M/s. Bikanerwala Foods Pvt. Ltd, located at A-28, Lawrence Road, Industrial Area, New Delhi-110035.
2. The Dy. Health Officer, MCD, Karol Bagh Zone, Public health department, Karol Bagh Zone, Anand Parbat, New Delhi -110005. Email Id : - (dhowest zone@gmail.com).
3. The Executive Engineer (Building), MCD, vishal Enclave, Rajouri Garden, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The Second floor shall not be re-constructed / use for any purpose.

2/19

## INSPECTION REPORT

1. Name & address of the building	Bikanerwala Foods Pvt. Ltd, Located at -A-28, Lawrence Road, Industrial Area, New Delhi-110035.
2. Type of Occupancy	Industry (Basement + Ground +one upper floor & Tin shed shed at terrace).
3. Type of Case	Renewal
4. Details of previous sNOC	F.6/DFS/MS/WZ/2020/60 dated 23/01/2020
5. Fire Safety directives letter No	F6/DFS/MS/BP/1996/242 dated 20/02/1996
6. Date of inspection	06/01/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Pushpender
9. Year of Construction	N/A
10. Applicant's letter No.	Email dated 13/12/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement/As per prev. insp. report dtd.-13/11/2019	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> </ul>	9 m	12 m Provided	MR
		Old Case	370 cm Provided	MR being old case
	<ul style="list-style-type: none"> <li>Width of internal road</li> </ul>	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	02	Provided	MR
		02	Provided	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	2 X 1.2 m (Old Case)	1x92cm, 1x140cm, 1x120cm	MR being old case
		2 X 1.2 m (Old Case)	1 x 140cm, 1 x 117 cm	MR being old case
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	Required	Provided	MR
		Required	Provided	MR
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	Old Case	Provided	MR being old case
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	Required	Provided	MR
		NA	NA	NA

*[Signature]*

5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	12 CO <sub>2</sub> , ABC type ISI marked	Provided Provided Provided	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 30m 5mm	Provided Provided Provided	MR MR MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required NA NA	Provided <del>Required</del> NA NA	MR NA NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA NA NA	NA NA NA	NA NA NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	Required Required	Provided Provided	MR MR
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	NA NA NA NA NA NA NA NA NA 900 & 1320 lpm 40 m Required Required	NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA MR MR MR MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	1,00,000 ltrs NR NR NR 12,500 ltrs	Provided NR NR NR Provided	MR NR NR NR MR

hp

M/21

		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/WZ/2020/60 Dated- 23/01/2020 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

421/AVS/MN  
09/01/2023

~~DO (work)~~

~~Signature~~  
10/11/2023

Signature of the Inspecting Officer  
(Sarabjeet Singh)  
Asst. Divisional Officer (MN)

DO (MN)  
09/01/2023

~~Signature~~  
11/01/2023

~~DO (MN)~~

Sign on entry side.

~~Signature~~  
13/11/2023

~~DO work~~  
~~performance~~

Signed in both side inspection  
~~Signature~~  
16/11/2023

~~DO (MN)~~

~~DO M.N.~~