

C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2023 / School/WZ/ 43

Dated: 20/01/2023

FIRE SAFETY CERTIFICATE

Certified that the **M.C. Primary Co-ed School** located at **Auchandi, Delhi-110039** comprised of Ground and first floor owned/occupied by **M C Primary Co-ed School** was issued FSC by this department vide letter No F6/DFS/MS/School/2019/1272 dated 14.06.2019. The premises was inspected by the officer concerned of this department on 05.01.2023 in the presence of Smt. Anju (In-charge), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from ..20/01/2023.. for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on ..20/01/2023.. at New Delhi

Yours faithfully

(Dharampal Bhardwaj)
Dy. CHIEF FIRE OFFICER
WEST ZONE

Copy to :-

1. The Director, Education, North MCD, Civic Center, New Delhi.
2. The Principal, MC Primary Co-ed School, Auchandi, Delhi-39.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Nr 14

INSPECTION REPORT

- N/A
- N/
1. Name & address of the building : M.C.D. Primary Co-ed School , Auchandi , Delhi-110039.
 2. Type of Occupancy : Educational
 3. Building comprised : Ground + One upper floor
 4. Type of Case : Renewal
 5. Details of Previous NOC : Letter No. F.6/DPS/MS/School/2019/1272 Dated-14/06/2019
 6. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
 7. Date of inspection : 05/01/2023
 8. Name of Inspecting Officer : ADO R K Sinha
 9. Name and designation of officers : Smt. Anju (Incharge)
From the building side : 2003
 10. Year of Construction : E Mail id, Dated-26/12/2022
 11. Applicant's letter No.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building <ul style="list-style-type: none"> Road width Gate width Width of internal road 	6.0 m 4.5 m NA	6.0 m 3.40 m NA	MR MR (old case) NA
2.	Number, Width, Type & Arrangement of Exits <ol style="list-style-type: none"> Number of staircases <ul style="list-style-type: none"> Upper Floors Basements Width of staircases <ul style="list-style-type: none"> Upper Floor Basements Protection of exits <ul style="list-style-type: none"> Fire check door Pressurization No. of continuous staircases to terrace Width of Corridor Door Size 	NA 01 NA NA 1.50 m NA NA NA NA NA NA NA	NA 02 NA NA NA Provided NA NA NA NA NA NA	NA MR NA NA MR NA NA NA NA NA NA NA
3.	Compartmentation <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System <ul style="list-style-type: none"> Basements Upper floors 	NA 12 a/c per hour	NA Natural Ventilated	NA MR

R

2-15

5.	Fire Extinguishers			
	• Total numbers	03	05	MR
	• Types	ABC	ABC	MR
	• IS marking	Yes	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA

2

	<ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		-	-	-
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

N-12

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01.03.2011 it is recommended to renew the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2019/1272.

Do (p/w)

10/01/2023
by c/o (w2)

18/1/2023

Do / N.W Do (w) on leave

Dr. F.T letter in pump for sign plane

Do
ADO (B.W)
18/1/23

Do (f/w 2)

20/1/2023

ms/ cell

Do
ADO (B.W)
06/1/23

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/BW