

DFA 26
27 27
2023

C.6
C.7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/EH/2023/SZ/ 26

Dated 19/01/2023

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of **M/s HABBIT (Shri Ji IMPEX)** located GF & FF, at Plot No 61, Basant Lok Vasant Vihar, New Delhi-110057 in the building comprised of Basement, Ground plus Two Upper Floors owned/occupied by Ms. Richi Khandelwal have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 16/01/2023 in the presence of Mr. Uday Panday and that the premise is fit for occupancy class **Group-D Assembly Building (Restaurant at GF & First Floor only)** with effect from 19/01/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/01/2023 at New Delhi by


(ATUL GARG)
DIRECTOR

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi- 110016 (Ref. MHA Portal ID 2022111120039 dated 09/12/2022)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

Name & Address of the Building

M/s HABBEE (Unit of Bharat DAFI & Co) located GF & FF at Plot No. 01, Dasmu Lok, Anand Vihar, New Delhi - 110029

Type of Occupancy

Assembly Building Group I Restaurant

Building Composed of

Basement Ground plus Two Upper Floors Restaurant at Ground & FF Floor only

Type of Case

New Case

Details of Previous NCR

Nil

Fire Safety Inspection Letter No.

FD/MS/MS/2021/27/150 dated 05/02/2021 by PVR Priya Cinema

Date of Inspection

16/01/2024

Name of the Inspecting Officers

Sb. Rajesh Kumar ADO (DC P)

Name & Designation of Officers from the Building side

Mr. Uday Paulay

Year of construction

1980

Applicant letter No.

MHA Portal ID 2022111120049 dated 09/12/2022

Minimum standards on Fire Prevention and Fire Safety I-R A

Requirement/ Existing Fire Protection	Provided at Site	Remarks MR/MR
---------------------------------------	------------------	---------------

1	Access to Building. ISCI No. FD/MS/MS/2021/27/150 dated 05/02/2021 by PVR Priya Cinema <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9m 6m N/A	Provided* Provided* Provided*	MR MR MR
2	Number, width, type and arrangements of exits. <ul style="list-style-type: none"> a. Number of Staircase <ul style="list-style-type: none"> • Upper floors • Basement floor b. Width of Staircase <ul style="list-style-type: none"> • Upper floors • Basement floor c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization d. No. of continuous staircase to terrace e. Width of corridor f. Door size 	Provided & Maintained by PVR Priya Cinema 2 Nos 2 Nos Provided in PVR Priya Cinema 2 mt x 2 1.5m, 2m & 1.5m Provided in PVR Priya Cinema Required Required Required N/A 1.50 mt	Provided* Provided* Provided* Provided* Provided* Provided* Provided* N/A Provided*	MR MR MR MR MR MR MR MR MR
3	Compartmentation. <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	Required Required 2 hrs N/A N/A	Provided* Provided* Provided* N/A N/A	MR MR MR N/A N/A
4	Smoke Management system. <ul style="list-style-type: none"> • Basement • Upper floors 	Required Required	Provided* Exhaust fans provided	MR MR
5	Fire Extinguishers. <ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	20 Nos ISI marked	30 Nos ABC-04, W.CO ₂ -02 Provided	MR MR MR
6	First Aid Hose Reels. <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose-reel hose • Nozzle Diameter 	Hose Reel	Provided & Maintained by PVR Priya Cinema 02 in Restaurant 30m 5mm	MR MR MR
7	Automatic Fire Detection and Alarming system.			

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Required	Smoke & Heat	MR
		Required	Provided*	MR
		N/A	N/A	N/A
		Required	Provided*	MR
		Required	Provided*	MR
8.	MOEFA	Required	Provided*	MR
9.	Public Address System	Required	Provided*	MR
10.	Automatic Sprinkler System	Provided & Maintained by PVR Priya Cinema		
	<ul style="list-style-type: none"> Basement 	Required	Provided*	MR
	<ul style="list-style-type: none"> Upper floors 	Required	Provided in Restt.	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants.	Provided & Maintained by PVR Priya Cinema		
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	Required	Provided*	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	Required	Provided*	MR
	<ul style="list-style-type: none"> Hose box. 	Required	Provided*	MR
12.	Yard Hydrants.	Provided & Maintained by PVR Priya Cinema		
	<ul style="list-style-type: none"> Total number of hydrants. 	Required	Provided*	MR
	<ul style="list-style-type: none"> 2. Hose box. 	Required	Provided*	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 	Provided & Maintained by PVR Priya Cinema		
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	2280 LPM	Provided*	MR
	<ul style="list-style-type: none"> ➤ Head of main pump. 	70 mtr	Provided*	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	Two	Provided*	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	180 LPM	Provided*	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	70 mtr	Provided*	MR
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	2280 LPM	Provided*	MR
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	70 mtr	Provided*	MR
	<ul style="list-style-type: none"> ➤ Auto Starting / Manual Stopping. 	Required	Provided*	MR
	<ul style="list-style-type: none"> ➤ Access to pump house 	Required	Provided*	MR
	<ul style="list-style-type: none"> Terrace Level 	Provided & Maintained by PVR Priya Cinema		
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	900 LPM	Provided*	MR
	<ul style="list-style-type: none"> ➤ Head of pump. 	35 m	Provided*	MR
	<ul style="list-style-type: none"> ➤ Power supply. 	Required	Provided*	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	Required	Provided*	MR
14.	Captive water storage for Fire Fighting.	Provided & Maintained by PVR Priya Cinema		
	<ul style="list-style-type: none"> Underground tank capacity. 	2,00,000 Ltrs	Provided*	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	Required	Provided*	MR
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	Required	Provided*	MR
	<ul style="list-style-type: none"> ➤ Access to tank. 	Required	Provided*	MR
	<ul style="list-style-type: none"> Overhead tank capacity. 	20,000 Ltrs	Provided*	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	Provided & Maintained by PVR Priya Cinema		
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	Required	Provided*	MR
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	Required	Provided*	MR
	<ul style="list-style-type: none"> Communication in lift car. 	Required	Provided*	MR
	<ul style="list-style-type: none"> Fireman's switch. 	Required	Provided*	MR
	<ul style="list-style-type: none"> Lift signage. 	Required	Provided*	MR
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A
19.	Fire Control Room.	Provided & Maintained by PVR Priya Cinema		
	<ul style="list-style-type: none"> Detector System Panel. 	Required	Provided*	MR
	<ul style="list-style-type: none"> Flow Switch Panel. 	Required	Provided*	MR

✓

[Handwritten signature]

[Handwritten mark]

MR
MR
N A
MR
M
N

20.	Special Fire Protection System for the Protection of special Risk, if any :	PA system Panel	Required	Provided*	MR
		Battery backup	Required	Provided*	MR
		Building floor plan	Required	Provided*	MR
			Required	Provided*	MR

Note - *Fire Safety arrangements Provided & Maintained by PVR Priya Cinema

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

14/16/1/2023

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO / BCP

DO (SD)

~~msb~~
16/1/23.

~~Dy EFO (S2)~~

In all cases where restaurant at above ground floor in such buildings, mention width of required staircases and no. of required staircases.

C. # 0. ~~1/1/23~~
17/01/2023

~~ADO (BCP)~~

There are two staircases facilitating to Restaurant located at GF & FF having width of 2.0 m & 1.50 m.

14/18/1/2023

~~EFO/S2~~ ~~19/01/2023~~

~~Deputa~~ ~~19/1/23~~
~~AD/mr~~

FFPS