



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/NDZ/2022/ 27

Dated: 23/01/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Masala Kitchen located at C-61, First Floor, Vikas Marg, Preet Vihar, Delhi - 110091, building comprised of Ground + 03 Upper Floors but Restaurant is running on 1st Floor only owned/occupied by M/s Masala Kitchen, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 28/12/2022 in the presence of Sh. Satyendra (Manager) and found that the building/premises is fit for occupancy class "Assembly" (Group D) / Eating House with effect from 23/01/2023 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 23/01/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. Masala Kitchen located at C-61, First Floor, Vikas Marg, Preet Vihar, Delhi - 110091.
2. The Deputy Commissioner (Licensing), 1st Floor, Police Station Defence Colony, New Delhi-110024 w.r.t. Online Application ID no. 2022121521374 Dated 15/12/2022.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [subrule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

N/3

INSPECTION REPORT

1. Name & address of the building: M/s Masala Kitchen, C-61, First Floor, Vikas Marg, Preet Vihar, Delhi - 110091.
2. Building is comprised of : Ground plus Three upper floors (Restaurant is running on 1st Floor only.
3. Type of Occupancy : Assembly (Restaurant)
4. Type of Case : New
5. Details of previous NOC : N/A
6. Fire Safety directives Letter No.: N/A
7. Date of inspection : 28/12/2022
8. Name of the Inspecting Officer : D.O. (E.D.)
9. Name and designation of Officer from the building side : Sh. Satyendra (Manager)
10. Year of Construction : 1982
11. Applicant's Online ID No. : 2022121521374 Dated 15/12/2022

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	12 m	60 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	1.50 m each	1.50 m x 2 & 1.10 m x 1	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door size	1.5 m	1.50 x 2 & 1.10 x 1	MR
3	Compartmentation			
	• Fire check Door	Required	Provided	MR ✓
	• Sealing of electrical Shafts	N/A	N/A	N/A
	• Fire rating of Shaft Door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	12 a/c per hour	Natural	MR ✓
5	Fire Extinguishers			
	• Total Numbers	02 Nos.	06 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR ✓
	• IS Marking	ISI Marked	ISI Marked	MR

(Handwritten Signature)

6	First-aid-Hose Reels			
	Total numbers of each floor	01 Nos.	01 Nos.	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's Location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false Ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of rise/down-comer	100 mm	100 mm	MR
	• Number of Hydrants per Floor	01 nos.	01 nos.	MR
	• Hose Box	01 nos.	01 nos.	MR
12	Yard Hydrants			
	• Total number of Hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13				
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main Pumps	N/A	N/A	N/A
	➤ Jockey pump output	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump output	N/A	N/A	N/A
	➤ Standby pump head	N/A	N/A	N/A
	➤ Auto starting/Manual stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• overhead Tank capacity	20,000 Ltrs.	Provided	MR
15	Exit Signage	Required	Provided	MR

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended please.

Ashok Kumar Jaiswal
28/12/2022

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East. Div.).

~~Dy. C.F.O. (N/52)~~

King
29/12/22

C.F.O.
30/12/2022

Director
30/12/22

1- what is the meaning of rest of the floor
2 Reason for doing 1st floor alone

King
30/12/22

C.F.O. Clarify the above.

~~Dy. C.F.O. (N/52)~~

King
02/01/2023
F.T.O.