

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F-6/DFS/MS/SZ/2023/ 34

Dated: 24/01/2023

FIRE SAFETY CERTIFICATE

Certified that the **Video Game Parlour** Located at **4th floor, Vegas Mall, Plot No 6, Sector 14, Dwarka, New Delhi**, in a building comprised of 4 Basement + Ground + 05 Upper Floors owned/ occupied by "Citymax Hotels (India) Pvt. Ltd. (Funcity)" was issued FSC vide letter No. F6/DFS/MS/Assembly/2019/SZ/2388, dated 31/12/19. (Issued to Mall F6/DFS/MS/SZ/2022/62 dated 09/12/2022) The premises was re - inspected by the team of officers concerned of this department on 18/01/2023 in the presence of Mr. Amit (Employee) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly" Group D (4th floor) with effect from 24/01/2023 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 24/01/2023 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, New Delhi.
2. The Manager, Video Game Parlour Located at 4th floor Vegas Mall Plot No 6, Sector 14, Dwarka, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/24

INSPECTION REPORT

1. Name & address of the building: Video Game Parlour A unit of "Citymax Hotels India Pvt. Ltd. (Funcity)" Located at 4th floor Vegas Mall Plot No 6, Sector 14, Dwarka, New Delhi.
2. Type of Occupancy : Class-D (Assembly) (**At 4th Floor in the Mall**)
3. Type of Case : Renewal
4. Details of previous NOC: F6/DFS/MS/Assembly/2019/SZ/2388, dated 31/12/19
(**Issued to mall - F6/DFS/MS/SZ/2022/62, dated 09/12/2022**)
5. Fire Safety directives Letter No. :F6/DFS/MS/BP/2016/326 Dated 16/12/2016 (**issued to mall**)
6. Date of inspection : 18/01/2023
7. Name of the Inspecting Officer ; DO SW & ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Amit (Employee)
9. Year of Construction : 2019
10. Applicant's letter No : Email dated 10-01-2023

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building (Same as Vegas mall)			
	• Road width	12 mtrs	Provided	MR
	• Gate width	06 mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits (Common With Mall)			
	a. Number of staircases	Required	Provided (by Mall) 03 nos near this occupancy	MR
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	1.5 m x3 each	Provided	MR
	• Upper floors	NA	Provided	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization .	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m X 02 Nos.	2x2m & 3x1.5m	MR
3.	Compartmentation(Common With Mall)			
	• Fire check door	Required	Provided by Mall	MR
	• Sealing of electrical shafts	Required	Provided by Mall	MR
	• Fire Rating of shaft door	Required	Provided by Mall	MR
	• Water Curtain	Required	Provided by Mall	MR
	• Fire Dampers	Required	Provided by Mall	MR




11/25

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		12 a/c per hour	Provided by Mall	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	03 nos. each type ABC, CO2 ISI marked	Provided Provided Provided	MR MR MR
6.	First - Aid Hose Reel	Common with mall		
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Required 36 m 5 mm	Provided By Mall Provided by Mall Provided by Mall	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke/ Heat Required Required Required Required	Provided Provided Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided by Mail	MR
10.	Automatic Sprinkler System (Common with mall)			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required Required Required	Provided by Mall Provided by Mall Provided by Mall	MR MR MR
11.	Internal Hydrants: (common with the mall)			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm 1 Required	Provided By Mall Provided By Mall Provided By Mall	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	Provided by Mall Provided by Mall	NA NA
13.	Pumping Arrangements: Common with Mall			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 900lpm 40 m Required Required	2850 LPM Provided By Mall 120 mtr Provided By Mall 2 electri Provided By Mall 180 LPM 2 Nos+Water Curtain Pump 2280 LPM Provided By Mall 120 mtr+Water Curtain 60 mtrs Provided By Mall 2850 LPM Provided By Mall 120mtr Provided By Mall Provided By Mall Provided By Mall Provided By Mall	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR

(Handwritten signature)

14.	Captive water Storage for fire fighting: Common with Mall		
	• Under ground tank capacity	NA	400000 l (By Mall) NA
	➤ Draw off connection	NA	Provided By Mall NA
	➤ Fire service inlet	NA	Provided By Mall NA
	➤ Access to tank	NA	Provided By Mall NA
	• Overhead Tank capacity	20, 000 litres	Provided By Mall MR
15.	Exit Signage	Required	Provided By Mall MR
16.	Provision of Lifts Common with Mall		
	➤ Pressurization of Lift Shaft	NA	Provided By Mall NA
	➤ Pressurization of lift lobby	NA	Provided By Mall NA
	➤ Communication in lift Car	NA	Provided By Mall NA
	➤ Fireman's Grounding Switch	NA	Provided By Mall NA
	➤ Lift Signage	NA	Provided By Mall NA
17.	Standby power supply	Required	Provided By Mall MR
18.	Refuge Area		
	➤ Total area	NA	Provided NA
	➤ Location	NA	Provided NA
19.	Fire control room (Common with Mall)		
	➤ Detector system panel	NA	Provided By Mall NA
	➤ Flow Switch Panel	NA	Provided By Mall NA
	➤ PA System Panel	NA	Provided By Mall NA
	➤ Battery backup	NA	Provided By Mall NA
	➤ Building Floor Plans	NA	Provided By Mall NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided By Mall NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/Assembly/2019/SZ/2388, dated 31/12/19 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

[Handwritten Signature]
18/1/23

Signature of the Inspecting Officer
Name: Sh. Vedpal
Designation: DO/SW

[Handwritten Signature]
18/1/23

Signature of the Inspecting Officer
Name: Udai Vir Singh
Designation: ADO/DWK

[Handwritten Signature]
Dyego (SZ)

[Handwritten Signature]
19/1

[Handwritten Signature]
ADO DWK

Six pt. letter to put up for sign plz
[Handwritten Signature]
18/1/23

[Handwritten Signature]
Dyego/SZ

[Handwritten Signature]
M. S. Ull