



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001


No: F.6/DFS/MS/School/WZ/2023/ 49

Dated: 24/01/23

FIRE SAFETY CERTIFICATE

Certified that the **MCD Primary School (ID-1556048)** Located at **A.D. Block, Tagore Garden, New Delhi -110027** comprised of Ground + 01 Upper floor, Owned/occupied by **MCD Primary School (ID-1556048)**, was issued FSC vide letter No. F6/DFS/MS/SCHOOL/2019/2249 dated 03/12/2019, The premises have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Circular no. 3298-3398 dated 01/03/2011 and verified by the officer concerned by the fire service on 04/01/2023 in the presence of sh. Rajender Singh (H.O.S.) and that the building/premises is fit for occupancy class "Educational" Group-B, with effect from 24/01/2023.....for a period of three years in accordance with the circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/ Condition mentioned below.

Issued on .24/01/2023 at New Delhi.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Principal, MCD Primary School (ID-1556048) at A.D. Block, Tagore Garden, New Delhi -110027.
2. Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: MCD Primary School (ID-1556048) Located at A.D. Block, Tagore Garden, New Delhi -110027
2. Type of Occupancy : Educational (Ground + 01 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2019/2249 dated 03/12/2019
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 04/01/2023
7. Name of the Inspecting Officers : Sarabjeet Singh ADO(MN)
8. Name and designation of officers from the building side : Sh. Rajender Singh (H.O.S.)
9. Year of Construction : 2013 (As Per Prev. Insp. Report dated: - 25/11/2019)
10. Applicant's letter No. : Outdoor Diary No:- 7878 dated: - 11/11/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 01/03/2011 As Per Pre. Insp. Report dtd:- 25/11/2019	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Required	03 Provided	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases			
	• Upper Floors	1.5 mts	1 x 1.65 cm, 1 x 1.63 cm & 1X 168 cm Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	03	03 Provided	MR
	f. Width of Corridor	1.5 mts	215 cm Provided	MR
	g. Door Size	1 mts	2 x 110cm Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	04 nos.	06 Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

[Handwritten signature]

[Handwritten signature]

6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA

	<ul style="list-style-type: none"> Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required as under the rules the NOC issued vide letter no. F6/DFS/MS/SCHOOL/2019/2249 dated: - 03/12/2019 renewal circular according to Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 is recommended.

~~Do (w2)~~

~~Signature~~
06/01/2023

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

CC. No. 760
DATED 06/01/23

~~Signature~~
6/1/2023

~~Defo (w2)~~

~~Signature~~
9/1/2023

~~ADO/M.N~~

Sir, F.T is put up for your kind personal & signature please.

~~Q9 CRO (w2)~~

~~Signature~~
28/1/2023

~~Signature~~
13/01/2023

ne 8/ ceep