

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2023/CNG/40

Dated: 27/01/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Hybrid CNG filling station outside DTC Depot, Sector-8, Dwarka, New Delhi comprised of ground floor only was issued Fire Safety Certificate vide letter No. F6/DFS/MS/CNG/2019/SZ/2300, dated 11/12/19. The premises was re inspected by the officer concerned of this department on 20/01/2023 in the presence of Sh. Sanchit Shehrawat (Employee) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Hazardous" (CNG filling station) with effect from 27/01/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/01/2023 at New Delhi by.



(Sunil Chaudhary)  
Dy. Chief Fire Officer,  
Delhi Fire Service.

Copy to:

1. Sh. Alok Sharma, Vice President-Fire & Safety IGL Bhawan, Plot No-4, Community Center, R K Puram Sec-9, New Delhi.
2. Sh. Ajay Khatri DGM – Fire & Safety IGL Bhawan, Plot No-4, Community Center, R K Puram Sec-9, New Delhi.
3. The Manager Hybrid CNG filling station outside DTC Depot, Sector-8, Dwarka, New Delhi.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement strictly shall be kept vacant as seen during inspection.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/19

**INSPECTION REPORT**

1. Name & address of the building : Hybrid CNG filling station outside DTC Depot, Sector-8, Dwarka, New Delhi.
2. Type of Occupancy : Group J: Hazardous (CNG Filling Station)
3. Type of Case : Renewal (Ground floor)
4. Details of previous NOC: F6/DFS/MS/CNG/2019/SZ/2300 dated 11/12/19.
5. Fire Safety directives Letter No. : UBBL/NBC Requirements/OISD-179
6. Date of inspection :20/01/2023
7. Name of the Inspecting Officer :Sh.Udai vir singh, ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. Sanchit Shehrawat (Employee)
9. Year of Construction : 2009
10. Applicant's letter No. : IGL/F&S/2021/15/78/1, dated 13/12/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/11, N/12 & N/13	Provided at site	Remarks MR/NMR
1.	<b>Access of building</b>			
	• Road width	06 m	Provided	MR
	• Gate width	4.5m	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, width, Type &amp; Arrangements of exits</b>			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	01	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke managements System</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA



11/18  
N/20

5.	Fire Extinguishers			
	• Total numbers	09 nos.	Co <sub>2</sub> 4.5 kg ( 5Nos.) DCP 10 kg (14 nos) in depot station & additional 02 nos ABC 9 kg	MR
	• Types	DCP & CO <sub>2</sub>	01 DCP Trolley of 75 kg & water mist trolley	MR
	• IS marking	Required	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	Gas & Flame detectors		Provided
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Ground Floor	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	✓ Head of main pump	NA	NA	NA
	✓ Number of main pumps	NA	NA	NA
	✓ Jockey pump out put	NA	NA	NA
	✓ Jockey pump head	NA	NA	NA
	✓ Standby Pump out put	NA	NA	NA
	✓ Standby Pump Head	NA	NA	NA
	✓ Auto Staring/Manual stopping	NA	NA	NA
	✓ Pump House Access	NA	NA	NA
	• Terrace level			
	✓ Discharge of pump	NA	NA	NA
	✓ Head of the pump	NA	NA	NA
	✓ Power supply	NA	NA	NA
	✓ Auto starting of pump	NA	NA	NA

 

MR

N/21

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage	Required no smoking board		Provided MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Connected with Depot CNG station	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 Flooding	Provided for compressor	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/CNG/2019/SZ/2300, dated 11/12/19 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name *Uday Vir Singh*

Designation *ADD/OWK*

*20/11/25*  
*20/11/23*  
*dyefo (S2)*  
*A. A. (S2)*