



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/EH/2023/NDZ/ 32

Dated: 27/01/2023

Certified that the M/s Zaika Bazar located at Plot No. 6, Parmesh Complex II, Karkardooma Community Centre, Delhi-110092, comprised of Ground plus two upper floors, owned/occupied by Narson Foods Pvt. Ltd. was issued FSC vide letter No. F.6/DFS/MS/EH/2019/NDZ/2310 dated 12/12/19. The premises was re-inspected by the officers concerned of this department on dated **23/01/2023** in the presence of Mr. Raj Nath Bhatt, Manager and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and observed that the building/premises is fit for occupancy **Group D "Assembly"** with effect from 27/01/2023 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 27/01/2023 at New Delhi by


(S. K. DUA)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE
o/c e.

To,

Mrs. Poonam Dhingra,
House No. 92, Hargobind Enclave-110092

Copy to: -

The Joint Commissioner (Lic.),
1st floor Police Station Defence Colony, New Delhi
MHA ID No. 2022042308070

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/19

1. Name & address of the building : Zaika Bazar
6, Parmesh Complex II,
Karkardooma Community Centre, Delhi-92
2. Building is comprised of : Ground plus two upper floors
3. Type of Occupancy : Assembly building (Restaurant)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/EH/2019/NDZ/2310 dt 12/12/19
6. Fire Safety directive letter No : Old requirements letter dated 24/12/2004
7. Date of Inspection : 23/01/2023
8. Name of the Inspecting officers : ADO (Shah)
9. Name and designation of Officer from the building side : Mr. Raj Nath Bhatt, Manager
10. Year of Construction : 2002
11. Applicant's letter No : 2023011300512 dated 17/01/2023

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirement as per letter 24/12/2004	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	N/A	30 mtr.	MR (old accepted)
		N/A	N/A	MR
		N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 nos.	03 nos.	MR
	<ul style="list-style-type: none"> • Upper floor • Basement 	N/A	N/A	N/A
	B. Width of Staircases	2.00 mtr	1.10 mtr, 0.90 mtr	MR (old accepted)
	<ul style="list-style-type: none"> • Upper floor • Basement 	N/A	0.70 mtr	N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
	g. Number of Door	N/A	GF-01 mtr, 0.80 mtr 1 st F-03 nos (0.80 mtr each)	MR (old accepted)
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A	N/A	N/A
		N/A	N/A	N/A
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	04 nos.	04 nos.	MR
		ABC /CO ₂	ABC /CO ₂	MR
		ISI marked	Provided	MR

Q.

N/20

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 nos	01 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	100 mm	N/A
	• Number of hydrants per floor	N/A	01 no.	N/A
	• Hose box	N/A	01 no.	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 Lpm	450 lpm	MR
	• Head of the pump	40 mtr	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	5,000 ltr	5,000 ltr	MR (old accepted)
15	Exit Signage.	Required	Provided	MR

Q.

21/21

16	Provision of Lifts			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter no F 6/DFS/MS/EH/2019/NDZ/2310 dated 12/12/19 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak
24/01/2023

Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : ADO (Shd)

~~DO(ED)~~

Submitted for approval please.

~~Dy. CFO (NDZ)~~

E.T. please.

Approval
24/01/2023

King
25/01/23

~~ADO (Shd.)~~

Sir, F.T. letter is put up for your kind signature pl.

Deepak