

C-60

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2023/ 55

Dated: 30/01/2023

FIRE SAFETY CERTIFICATE

Certified that the building of Shree Ram World School, Located at Sector – 10, Dwarka, New Delhi – 110075, comprised of Basement + Ground + 03 Upper Floor was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2020/SZ/63, dated 20/02/2020. The premises was re - inspected by the officer concerned of this department on 18/01/2023 in the presence of Ms. Sudha Sadangi (HOS) and found that the premises have deemed complied with the fire prevention and fire safety arrangements in accordance with DOE 3298-3398, dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from 30/1/23. for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/1/23..... at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, Shree Ram World School, Located at Sector – 10, Dwarka, New Delhi – 110075.

Following fire safety directives must be adhered to:- *-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/18

INSPECTION REPORT

1. Name & address of the building: Shree Ram World School, Located at Sector – 10, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Educational (Basement + Ground+ 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2020/SZ/63, dated 20/02/20
5. Fire Safety directives Letter No. : 3298-3398 dated 01/03/2011
6. Date of inspection : 18-01-2023
7. Name of the Inspecting Officer : Sh. Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side: Ms. Sudha Sadangi (HOS)
9. Year of Construction : 2014
10. Applicant's letter No. : Email dated 05/01/2023

Total Area = 8278.77 sqm.
Covered Area = 6255.34 sqm
Class rooms = 72
No. of students = 1643

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/11, N/12 & N/13	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	06 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 Nos.	03 Nos.	MR
	• Basements	03 Nos. + Ramp	3 Nos. + Ramp	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided	MR (Being old case)
	• Basements	1.5 m + 06 mtr wide ramp	Provided	MR (Being old case)
	c. Protection of exits			
	• Fire check door	Required	Provided at basement	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	03 Nos.	Provided	MR
	e. Width Of Corridor	02 mtr	Provided	MR
	f. Door Size	01 mtr	100 cm	MR
3.	Compartmentation			
	• Fire check door	Required	Provided at basement	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

N/19

4.	Smoke managements System				
	• Basements	30 a/c charge	Provided		MR
	• Upper floors	12 a/c charge	Natural ventilation		MR
5.	Fire Extinguishers				
	• Total numbers	40 nos.	Provided		MR
	• Types	ABC & CO ₂	ABC & CO ₂		MR
	• IS marking	ISI marked	ISI marked		MR
6.	First – Aid Hose Reels				
	• Total numbers on each floor	02 Nos.	Provided		MR
	• Length of hose reel hose	30 mtr	Provided		MR
	• Nozzle diameter	05 mm	Provided		MR
7.	Automatic fire detection and alarming system				
	• Type of detectors	NA	NA		NA
	• Location of Main Panel	NA	NA		NA
	• Location of Repeater Panel	NA	NA		NA
	• Alternate source of power	NA	NA		NA
	• Hooters' Location	NA	NA		NA
8.	MOEFA	NA	NA		NA
9.	Public Address System	NA	Provided		NA
10.	Automatic Sprinkler System				
	• Basements	Required	Provided in basement		MR
	• Upper Floor	NA	NA		NA
	• Sprinkler above false ceiling	NA	NA		NA
11.	Internal Hydrants:				
	• Size of riser/down- comer	Required	Provided in basement		MR
	• Number of hydrants per floor	03 Nos.	Provided		MR
	• Hose Box	03 Nos. per floor	Provided		MR
12.	Yard Hydrants				
	• Total number of hydrants	NA	NA		NA
	• Hose Box	NA	NA		NA
13.	Pumping Arrangements:				
	• Ground Level				
	• Discharge of main pump	NA	NA		NA
	➤ Head of main pump	NA	NA		NA
	➤ Number of main pumps	NA	NA		NA
	➤ Jockey pump out put	NA	NA		NA
	➤ Jockey pump head	NA	NA		NA
	➤ Standby Pump out put	NA	NA		NA
	➤ Standby Pump Head	NA	NA		NA
	➤ Auto staring/Manual stopping	NA	NA		NA
	➤ Pump House Access	NA	NA		NA
	• Terrace level				
	➤ Discharge of pump	900 lpm	Provided		MR
	➤ Head of the pump	40 mtr	Provided		MR
	➤ Power supply	Required	Provided		MR
	➤ Auto starting of pump	Required	Provided		MR

N

Signature

Nf20

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	50,000 ltr	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000 ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 & ABC, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2020/SZ/63, dated 20/02/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Sign of Inspecting Officer

Name *Uday Kumar Singh*

Designation *Inspector*

20/11/23

20/11/23

M. S. Singh