



No. F6/DFS/MS/2023/School/ 56

Dated: 30/01/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Rawalpindi Sanatan Dharma Senior Secondary School** located at **Sabzi Mandi, Malka Ganj Road, Delhi-110007** comprised of **Ground & 02 upper floors only** owned/occupied by the **Rawalpindi Sanatan Dharma Senior Secondary School** have complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no. 262-362 dated 17.01.2005 and verified by the officer concerned of Fire Service on **17.01.2023** in the presence of **Mr. Deepak Bhatia (Teacher)** and that the building/premises is fit for occupancy "**Group B Educational**" with effect from **...30/01/2023** for a period of three years, subject to compliance of the conditions mentioned below:

Issued on **...30/01/2023** at New Delhi

  
(Amit Gang)  
Director

Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. The Manager, Rawalpindi Sanatan Dharma Senior Secondary School located at Sabzi Mandi, Malka Ganj Road, Delhi-110007.

**Conditions for the validity of Fire Safety Certificate:**


1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doiit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

### INSPECTION REPORT

- 1 Name & address of the building : Rawalpindi Sanatan Dharma Sr. Sec. School located at Sabzi Mandi, Malka Ganj Road, Delhi-110007.
- 2 Type of Occupancy : Educational
- 3 Composition of building : Ground & 02 upper floors only
- 4 Type of Case : New Case ✓
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 30.11.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Deepak Bhatia
10. Year of Construction : 1980
11. Applicant's letter No. : Online E-mail dated: 23.11.2022

Plot Area-2247 sqm.      Covered Area: 2247 sqm.      No of class rooms -18      No of students---466

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular Dated: 17.01.2005 Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6m	6m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	01	02	MR ✓
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 m	1.40 m & 85cm	MR ✓
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	01m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	12 a/c per hour	NA	NA -
	• Upper floors	12 a/c per hour	Natural Ventilated	MR -
5	<b>Fire Extinguishers</b>			
	• Total numbers	08nos	Provided	MR ✓
	• Types	ABC/Co2	ABC-10	MR ✓
	• ISI marking	ISI Marked	Provided	MR ✓



N/15

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR ✓
	• Length of hose reel hose	30m	Provided	MR ✓
	• Nozzle diameter	5mm	Provided	MR ✓
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450lpm	450lpm	MR ✓
	➤ Head of the pump	40m	40m	MR ✓
➤ Power Supply	Required	Provided	MR ✓	
➤ Auto Starting of pump	Required	Provided	MR ✓	
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	50,000 LTR	NA ✓
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 LTR	Provided	MR ✓
15	<b>Exit Signage.</b>			
	Required	Provided	MR ✓	

Provision of Lifts.				
16	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. 737 dated 08.12.2022.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by Director of Education dated 17.01.2005, it is recommended to grant Fire Safety Certificate.

DO/NW - ON Leave

~~DO (Wst)~~

~~dy~~  
18/1/2023


~~DCFO (W2)~~

~~[Signature]~~  
19/1/2023

~~CFO~~  
19/01/2023

~~Director~~

~~[Signature]~~  
19/1/23

  
Signature of the Inspecting Officer  
Name :- C.L. Meena  
Designation:- ADO/RN

Conf... - B.T. O.