



No. F6/DFS/MS/Assembly/SZ/2023/ 42

Dated: 31/01/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Auditorium Building, National Academy of Medical Sciences (India), Located at Ansari Nagar, Mahatma Gandhi Marg, New Delhi-110029, comprised of small basement for electric panel only, ground + 1 upper floor, Auditorium at ground floor only without balcony was granted Fire Safety Certificate (FSC) by this department vide letter no. F6/DFS/MS/Audi/2020/SZ/30 dated 14.01.2020. The building/premises was re-inspected by Assistant Divisional Officer (M. Road) from this department on 24.01.2023 in the presence of Mr. Nirmal Singh (Admin Officer) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of "Assembly Building Group D" (Auditorium at ground floor only) with effect from 31/01/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 31/01/2023 at New Delhi by

(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Dr. Umesh kapil (Secretary), M/s Auditorium Building, National Academy of Medical Sciences (India), Located at Ansari Nagar, Mahatma Gandhi Marg, New Delhi-110029.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. Basement shall be used as per NBC/UBBL
9. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

2/20

INSPECTION REPORT

1	Name & address of the building	M/s Auditorium Building at National Academy of Medical Sciences (India), Located at Ansari Nagar, Mahatma Gandhi Marg, New Delhi-110029.				
2	Building is comprised of	Basement + Ground +01 upper floor (Auditorium at ground floor without balcony & small basement for electrical panel only), offices at 1 st floor				
3	Type of occupancy	Group 'D' -Assembly Building				
4	Type of case	Renewal				
5	Details of previous FSC	F6/DFS/MS/Audi/2020/SZ/30 dated 14.01.2020.				
6	Fire safety directive letter no.	F6/DFS/MS/BP/94/1773 dated 15.12.1994				
7	Date of inspection	24.01.2023				
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M. Road)				
9	Name of the designation of officer From the building side	Mr. Nirmal Singh (Admin Officer)				
10	Year of construction	1998				
11	Applicant's letter no	Outdoor Diary no. 9540 dated 29.12.2022				
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement as per NBC/UBBL	Provided at Site	Remarks MR/NMR		
1	Access to building					
	a	Road width	Accessible	24.0 mtrs	MR	
	b	Gate width	5.0 mtrs	5.0 mtrs	MR	
	c	Width of internal road	NA	NA	NA	
2	Number, Width, Type and Arrangement of Exits					
	A	Number of staircases/ramp				
		a	Upper floor	01 no.	01 no.	MR
		b	Basement	01 no.	01 no.	MR
	B	Width of staircases				
		a	Upper floor	1.25 mtrs	1.40 mtrs	MR
		b	Basement	1.25 mtrs	1.25 mtrs	MR
	C	Protection of exits				
		a	Fire check door	Required	Provided in basement	MR
		b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace		01 no.	Provided	MR
	E	Width of corridor		1.20 mtrs	Provided	MR
	F	Door size		1.20 mtrs (each)	5 nos. of exit each 1.2 mtrs at Ground floor	MR
3	Compartmentation					
	a	Fire check door		Required	Provided in basement	MR
	b	Sealing of electrical shafts		Required	Provided	MR
	c	Fire rating of shaft door		NA	NA	NA
	d	Water curtain		NA	NA	NA
	e	Fire dampers		NA	NA	NA
4	Smoke Management System.					
	a	Basement		30 ACPH	Exhaust fan Provided	MR
	b	Upper floor		12 ACPH	Provided	MR

Mw RL


5.	Fire Extinguisher			
a	Total numbers	10 nos.	14 nos.	MR
b	Types	CO ₂ & ABC	CO ₂ & ABC	MR
c	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
a	Total numbers of each floor	02 nos. at GF only	Provided	MR
b	Length of hose reel hose	30 mtr.	Provided	MR
c	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
a	Type of detectors	NA	Heat & Smoke	NA
b	Location of main panel	NA	Ground floor	NA
c	Location of repeater panel	NA	NA	NA
d	Alternate source of power	NA	Provided	NA
e	Hooters	NA	Provided	NA
8	MOEFA	NA	Provided	NA
9	Public Address System.	NA	Provided	NA
10	Automatic Sprinkler System.			
a	Basement	NA	NA	NA
b	Upper floors	NA	NA	NA
c	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
a	Size of riser	NA	NA	NA
b	Number of hydrants per floor	NA	NA	NA
c	Hose Box	NA	NA	NA
12	Yard Hydrants.			
a	Total number of hydrants	NA	NA	NA
b	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
A	Ground Level			
a	Discharge of main Pump	Boosting	450 LPM	MR
b	Head of Main Pump	Required	40 m	MR
c	Number of main pumps	01 no.	01 no.	MR
d	Jockey pump out put	NA	NA	NA
e	Jockey pump head	NA	NA	NA
f	Standby pump out put	NA	NA	NA
g	Standby pump head	NA	NA	NA
h	Auto starting /manual stopping	Required	Provided	MR
i	Pump House Access	Required	Provided	MR
B	Terrace Level			
a	Discharge of pump	NA	NA	NA
b	Head of the Pump	NA	NA	NA
c	Power supply	NA	NA	NA
d	Auto Starting of pump	NA	NA	NA

14	Captive Water Storage for Fire Fighting.				
	a	Underground tank capacity	25,000 Ltrs	Provided	MR
	b	Draw-off connection	Required	Provided	MR
	c	Fire service inlet	Required	Provided	MR
	d	Access to tank	Required	Provided	MR
	e	Overhead Tank capacity	25,00 ltrs	10,000 ltrs	MR
15	Exit Signage.		Required	Provided	MR
16	Provision of Lifts.				
	a	Pressurization of Lift Shaft	NA	NA	NA
	b	Pressurization of Lift lobby	NA	NA	NA
	c	Communication in lift car	NA	NA	NA
	d	Firemen's grounding switch	NA	NA	NA
	e	Lift Signage	NA	NA	NA
17	Standby power supply		Required	Provided	MR
18	Refuge Area.				
	a	Total area	NA	NA	NA
	b	Location	NA	NA	NA
19	Fire Control Room				
	a	Detector system panel	NA	NA	NA
	b	Flow switch panel	NA	NA	NA
	c	PA system panel	NA	NA	NA
	d	Battery backup	Required	Provided	MR
	e	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:		Required	Co ₂ local flooring provided for electrical panel	MR

LEGENDS - Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided But Not Functional (PNF).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/Audi/2020/SZ/30 dated 14.01.2020 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.


 Signature of the Inspecting Officer
 Name Rajesh Kumar Shukla
 Designation ADO (M. Road)

DO (SD)

msk
27/1/23

DCB (S2)

F.F.

ADO (MRD) *F.F. is but cfb pls*
Dep. CEO (S2)

20/1/23

M.S. CV