

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No.F.6 DFS/MS/School/2023/SZ/ 579

Dated: 31/01/2023

FIRE SAFETY CERTIFICATE

Certified that the **Dr. B.R Ambedkar Adarsh Vidyalaya** located at Sector-5, Dakshin Puri, New Delhi 110062 comprised of Ground floor only owned/ occupied by Municipal Corporation of Delhi was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2020/SZ/11 Dated 13-01-2020. The said premise was re-inspected by officer concerned of this department on 21/01/2023 in presence of Mr. Dinesh Kumar and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 31/01/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 31/01/2023 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Dr. B.R Ambedkar Adarsh Vidyalaya at Sector-5, Dakshin Puri, New Delhi 110062
2. The Director of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Dr B R Ambedkar Adarsh Vidyalaya Sector-5, Dakshin Puri, New Delhi 110062		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2020/SZ/11 Dated 13-01-2020		
6	Fire Safety Directives Letter No	DOE Circular dated 17/01/2005		
7	Date of Inspection	21/01/2023		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Dinesh Kumar		
10	Year of construction	2006		
11	Applicant letter No.	Outdoor diary no 9690 dated 04/01/2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible NA -NA-	06 mtr 02 Nos-3 35m & 1.46m -NA-	MR NA -NA-
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	> Upper floors.	-NA-	-NA-	-NA-
	> Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	> Upper floors	-NA-	-NA-	-NA-
	> Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	> Fire check door	-NA-	-NA-	-NA-
	> Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	Provided	MR
3.	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	30 ACPH 12 ACPH	-NA- NA	-NA- NA
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	Required ABC / CO2 ISI marked	04 Nos ABC & CO2 Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-
7.	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	-NA-	-NA-	-NA-



	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	NA	-NA-	NA
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA-	-NA-	-NA-
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. Flow switch panel. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

/

ms

n/15



-NA-
-NA-
-NA-
-NA-
M
-N

	• PA system panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-NA-

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No F6/DFS/MS/School/2020/SZ/11 Dated 13-01-2020, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Accordingly DFA is put up for approval and signature please.

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

~~DO (SD)~~

must
25/1/23

DO (SD)

F.T.
Sh

ADO (BCP)

As approved, A.T. letter is put up for your signature P.

10/1/2023
30/1/2023

M.S. 11/1/23