



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001


No: F.6/DFS/MS/School/WZ/2023/ 60

Dated: 01/02/2023

FIRE SAFETY CERTIFICATE

Certified that the **Lal Public School** located at Ground floor only, **WZ-51, Ram Garh Colony, New Delhi -110015**, comprised of Ground + 01 Upper floor. Owned/occupied by **Lal Public School**, was issued FSC vide letter No. F6/DFS/MS/School/2017/1118 dated 28/07/2017. The premises was re- inspected by the officer concerned by this department on 13/01/2023 in the presence of Sh. Jasbeer Singh (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Circular No. 3298-3398 dated 01/03/2011 and that the premises is fit for occupancy class "Educational" Group-B, with effect from 01/01/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 Condition mentioned below.

Issued on at New Delhi.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. Sh. Jasbeer Singh (Manager), Lal Public School at WZ-51, Ram Garh Colony, New Delhi -110015.
2. Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Lal Public School Located at WZ-51, Ram Garh Colony, New Delhi-110015.
2. Type of Occupancy : Educational (Ground + 01 Upper Floor) School is running at ground floor only (05 rooms) Total Area=230 sqryd & covered Area 150 sqryd
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2017/1118 dated 28/07/2017
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 13/01/2023
7. Name of the Inspecting Officers : Sarabjeet Singh ADO(MN)
8. Name and designation of officers from the building side : Sh. Jasbeer Singh (Manager)
9. Year of Construction : 1995 (As Per Prev. Insp. Report dated: - 16/07/2017)
10. Applicant's letter No. : Outdoor Diary No.-9427 dated: - 23/12/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 01/03/2011 As Per Pre. Insp. Report dtd:- 16/07/2017	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1 mts	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	04 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
15	Exit Signage.	NA	Provided	NA

X

AS

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules DOE Circular no. 3298-3398 dated 01/03/2011, the NOC issued vide letter no. F6/DFS/MS/School/2017/1118 dated 28/07/2017 renewal under 35 of the Delhi Fire Service Rules 2010 is recommended.

~~DO (West)~~

~~Signature~~
18/01/2023

06/ADO/MN
18/01/2023

~~Signature~~
22/1/2023

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

~~DCO (m)~~
28/1/2023

D.O. (WEST) ... 608
DATED 20/01/2023

~~ADO (M.N)~~

Sir, F. T is put up for your kind personal & signatures please.

~~Signature~~
25/1/2023

~~Signature~~
25/01/2023

~~MSJ Cell~~